

REQUEST FOR ELECTRICAL INSPECTION

DATE: 3-30-21 TIME 11:15: AM / PM

JOB ADDRESS: 11105 S. Courtyard Squire

PERMIT NUMBER: 17745

INSPECTION DATE:

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

PASS	<u>FAIL</u>
DATE:	<u>3-30-21</u>
TIME:	<u>11:15</u>
INSPECTOR:	<u>Jason</u>

CONTRACTOR/CALLER NAME: M J Campbell Electric

CONTACT TEL/PGR/MOBILE: Malcolm 832-512-9098

INSPECTOR COMMENTS:

Master bath - Box above shower not enough clearance
Need to ground Metal Boxes

Reinspection fee required