

# REQUEST FOR ELECTRICAL INSPECTION

DATE: 3-18-21 TIME 10:30 AM / PM

JOB ADDRESS: 11207 Wilding

PERMIT NUMBER: 17714

INSPECTION DATE:

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- |                                |                          |                               |                          |
|--------------------------------|--------------------------|-------------------------------|--------------------------|
| 1. Temp Sump Pump Connection   | <input type="checkbox"/> | 1. Electrical Pool Cover      | <input type="checkbox"/> |
| 2. T-pole                      | <input type="checkbox"/> | 2. Electrical Pool Final      | <input type="checkbox"/> |
| 3. Ditch Cover                 | <input type="checkbox"/> | 1. Generator Ditch Cover      | <input type="checkbox"/> |
| 4. Slab Cover                  | <input type="checkbox"/> | 2. Generator Electrical Final | <input type="checkbox"/> |
| 5. <u>Wall / Ceiling Cover</u> | <input type="checkbox"/> | 1. Partial / See Comments     | <input type="checkbox"/> |
| 6. TCI                         | <input type="checkbox"/> |                               |                          |
| 7. Meter Loop And Service      | <input type="checkbox"/> |                               |                          |
| 8. Reconnect                   | <input type="checkbox"/> |                               |                          |
| 9. Electrical Final            | <input type="checkbox"/> |                               |                          |
| 10. Landscape Lighting Cover   | <input type="checkbox"/> |                               |                          |
| 11. Landscape Lighting Final   | <input type="checkbox"/> |                               |                          |

|  |                               |
|--|-------------------------------|
| <input checked="" type="checkbox"/> PASS | <input type="checkbox"/> FAIL |
| DATE: <u>3-18-21</u>                     |                               |
| TIME: <u>10:30</u>                       |                               |
| INSPECTOR: <u>Jason</u>                  |                               |

CONTRACTOR/CALLER NAME: Sotex Electric

CONTACT TEL/PGR/MOBILE: Jim 281-753-4323

INSPECTOR COMMENTS:

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

Reinspection fee required

# REQUEST FOR ELECTRICAL INSPECTION

DATE: 3-17-21 TIME 10:00: AM / PM

JOB ADDRESS: 11207 Wilding

PERMIT NUMBER: 17714

INSPECTION DATE:

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

PASS

**FAIL**

DATE: 3-17-21

TIME: 10:00

INSPECTOR: JB

CONTRACTOR/CALLER NAME: Sofex Electric

CONTACT TEL/PGR/MOBILE: Jim 281-753-4323

INSPECTOR COMMENTS:

wires to island need to be  
TTHN or UF type

Reinspection fee required