

REQUEST FOR INSPECTION

CALL DATE: 7-14-21 TIME: 12:10 AM PM

PROPERTY ADDRESS: 5 Memorial Point PERMIT NUMBER: 16312

INSPECTION INFORMATION

INSPECTOR: Bob Baldwin Jason Bienek Gary Moran City Engineer _____

| | | |
|-------------------------------------|--------------------------------------|------------------------------------------------------------------|
| Demolition | Generator Concrete Steel Pad | Mechanical Cover |
| Temporary Tree Protection Fencing | Generator Final - Operative | Mechanical Vent Hood |
| Pre-Construction Site | Fence Post Hole | Mechanical Grill Seal |
| Piers | Fence Final | Mechanical Box Seal |
| Foundation Repair | Pool Stake Out & Pool Doc Box Set Up | Mechanical Air Make Up |
| Foundation Steel – Survey Verified | Deck Steel / Pool Steel | Mechanical Final |
| Hurricane Strapping – Exterior Wall | Deck Final | Mechanical Change Out |
| Wall Board Exterior | Pool Final | Mechanical Cover (Wine Room) |
| Ridge Height - Verification | Electrical T-Pole | Mechanical Final (Wine Room) |
| Stair Compliance | Electrical Cover | Sewer Disconnect |
| Framing Only | Electrical Ditch Cover | Plumbing Water Line |
| Frame Cover | Electrical TCI | Plumbing Sewer Line |
| Poly Seal | Pool Electrical Underground | Plumbing Ground |
| Insulation | Pool Electrical Cover | Plumbing Shower Pan/Wall Board |
| Wall Board Interior | Pool Electrical Final | Plumbing Gas (GT0- House) |
| Brick Tie | <u>Electrical Final</u> | Plumbing Cover |
| Stucco Lathe | Temporary Drainage | Plumbing Final |
| Building Final | Drainage Partial | Pool Plumbing Cover |
| Irrigation Trench / Tree Final | Drainage Cover | Pool Plumbing Vacuum Breaker, P-Trap, Gas Final |
| Driveway / Steel | Drainage Final | Plumbing Pool Final |
| Driveway Final | Fire Sprinkler Cover | Water Heater Final |
| Sidewalk/Flatwork/Pavers Steel | Fire Sprinkler Final | Irrigation Final |
| Sidewalk/Flatwork/Paver Final | Other/Miscellaneous | <input checked="" type="radio"/> PASS <input type="radio"/> FAIL |

CONTRACTOR NAME: Pure Electrical

CONTACT PHONE/EMAIL: Robert 832-718-0552

INSPECTOR COMMENTS: _____

DATE: 7-14-21

TIME: 12:10

INSPECTOR: Jason

Re-Inspection Fee Required

REQUEST FOR INSPECTION

CALL DATE: 7-2-21 TIME 10:20 AM / PM
 PROPERTY ADDRESS: 5 Memorial Pt
 PERMIT NUMBER: 16312

INSPECTION INFORMATION

DATE PERFORMED: 7-2-21 TIME 10:20 AM / PM
 INSPECTOR: 1) Bob Baldwin _____
 2) Cary Moran _____
 3) City Engineer _____
 4) Jason Bienek _____
 5) Other _____

| | | |
|-------------------------------------|--------------------------------|-------------------------------------------------|
| Demolition (Main House) | Sidewalk/Flatwork/Pavers Steel | Electrical Ditch Cover |
| Demolition (Pool Only) | Sidewalk/Flatwork/Paver Final | Electrical TCI |
| Temporary Tree Protection Fencing | Generator Concrete Steel Pad | <u>Electrical Final</u> |
| Pre-Construction Site | Generator Final - Operative | Mechanical Vent Hood |
| Piers | Partial Trench Inspection | Mechanical Grill Seal |
| Foundation Repair | Trench Inspection | Mechanical Box Seal |
| Foundation Steel – Survey Verified | Irrigation Final | Mechanical Air Make Up |
| Hurricane Strapping – Exterior Wall | Fence Partial Post Hole | Mechanical Final |
| Wall Board Exterior | Fence Post Hole | Mechanical Cover (Wine Room) |
| Ridge Height | Fence Final | Mechanical Final (Wine Room) |
| Stair Compliance | Temporary Drainage | Fire Sprinkler Cover |
| Framing Only | Drainage Partial | Fire Sprinkler Final |
| Frame Cover | Drainage Cover | Pool Stake Out & Pool Doc Box Set Up |
| Poly Seal | Drainage Culvert | Deck Steel |
| Insulation | Drainage Final | Deck Final |
| Wall Board Interior | Plumbing Water Line | Pool Final |
| Brick Tie | Plumbing Sewer Line | Pool Electrical Underground |
| Stucco Lathe | Plumbing Ground | Pool Electrical Cover |
| Building Final | Plumbing Shower Pan/Wall Board | Pool Electrical Final |
| Tree Final | Plumbing Gas (GTO- House) | Pool Plumbing Cover |
| Driveway / Partial | Plumbing Cover | Pool Plumbing Vacuum Breaker, P-Trap, Gas Final |
| Driveway / Steel | Plumbing Final | Plumbing Pool Final |
| Driveway Final | Electrical T-Pole | Water Heater Final |

CONTRACTOR NAME: Pure Electrical

CONTACT PHONE/EMAIL: Robert 832-718-0552

INSPECTOR COMMENTS: _____

Need correct size breakers on A/C
Need ladder to check attic devices and spot furnace

| |
|-------------------------|
| PASS <u>FAIL</u> |
| DATE: <u>7-2-21</u> |
| TIME: <u>10:20</u> |
| INSPECTOR: <u>Jason</u> |

Re-Inspection Fee Required