

REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-03-14 TIME 12:00 AM / PM

JOB ADDRESS: 338 Turnbridge

PERMIT NUMBER: 12710

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)


- | | | | |
|------------------------------|-------------------------------------|-------------------------------|--------------------------|
| 1. Temp Sump Pump Connection | <input type="checkbox"/> | 1. Electrical Pool Cover | <input type="checkbox"/> |
| 2. T-pole | <input type="checkbox"/> | 2. Electrical Pool Final | <input type="checkbox"/> |
| 3. Ditch Cover | <input type="checkbox"/> | 1. Generator Ditch Cover | <input type="checkbox"/> |
| 4. Slab Cover | <input type="checkbox"/> | 2. Generator Electrical Final | <input type="checkbox"/> |
| 5. Wall / Ceiling Cover | <input type="checkbox"/> | 1. Partial / See Comments | <input type="checkbox"/> |
| 6. TCI | <input checked="" type="checkbox"/> | | |
| 7. Meter Loop And Service | <input type="checkbox"/> | | |
| 8. Reconnect | <input type="checkbox"/> | | |
| 9. Electrical Final | <input type="checkbox"/> | | |
| 10. Landscape Lighting Cover | <input type="checkbox"/> | | |
| 11. Landscape Lighting Final | <input type="checkbox"/> | | |

PASS	<u>FAIL</u>
DATE:	<u>1-31-14</u>
TIME:	<u>12:00</u>
INSPECTOR:	<u>JB</u>

CONTRACTOR/CALLER NAME: Jescon Electric

CONTACT TEL/PGR/MOBILE: VALENTIN 281-914-7939

INSPECTOR COMMENTS:



Need bonding bushing on nipple between Disconnect & Termster switch

Need to replace E.G.C. with correct size

Need to separate neutrals from grounds in gutter

Reinspection fee required