

# REQUEST FOR ELECTRICAL INSPECTION

DATE: 3-20-14 TIME 11:30 AM / PM  
JOB ADDRESS: 408 Chapelwood Ct  
PERMIT NUMBER: 13167

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2009 OF NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

|                      |      |
|----------------------|------|
| <u>PASS</u>          | FAIL |
| DATE: <u>3-20-14</u> |      |
| TIME: <u>11:30</u>   |      |
| INSPECTOR: <u>AB</u> |      |

CONTRACTOR/CALLER NAME: Harmony Elect  
CONTACT TEL/PGR/MOBILE: John 713-826-8103  
INSPECTOR COMMENTS:

*[Handwritten notes and scribbles in the inspector comments section]*



Reinspection fee required

# REQUEST FOR ELECTRICAL INSPECTION

DATE: 3-20-14 TIME 11:00: AM / PM

JOB ADDRESS: 206 Millbrook

PERMIT NUMBER: 13206

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2015 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienel 2) Dave Whittaker 3)

- |   |  |
|---|--|
| 1. Temp Sump Pump Connection <input type="checkbox"/> | 1. Electrical Pool Cover <input checked="" type="checkbox"/> |
| 2. T-pole <input type="checkbox"/>                    | 2. Electrical Pool Final <input type="checkbox"/>            |
| 3. Ditch Cover <input type="checkbox"/>               | 1. Generator Ditch Cover <input type="checkbox"/>            |
| 4. Slab Cover <input type="checkbox"/>                | 2. Generator Electrical Final <input type="checkbox"/>       |
| 5. Wall / Ceiling Cover <input type="checkbox"/>      | 1. Partial / See Comments <input type="checkbox"/>           |
| 6. TCI <input type="checkbox"/>                       |  |
| 7. Meter Loop And Service <input type="checkbox"/>    |  |
| 8. Reconnect <input type="checkbox"/>                 |  |
| 9. Electrical Final <input type="checkbox"/>          |  |
| 10. Landscape Lighting Cover <input type="checkbox"/> |  |
| 11. Landscape Lighting Final <input type="checkbox"/> |  |

|                      |      |
|----------------------|------|
| <u>PASS</u>          | FAIL |
| DATE: <u>3-20-14</u> |      |
| TIME: <u>11:00</u>   |      |
| INSPECTOR: <u>JB</u> |      |

CONTRACTOR/CALLER NAME: Walter Gerns Elect

CONTACT TEL/PGR/MOBILE: Walter 281-831-4252

INSPECTOR COMMENTS: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Reinspection fee required

# REQUEST FOR ELECTRICAL INSPECTION

DATE: 3-20-14 TIME 1:00: AM/PM  
JOB ADDRESS: 11509 MAY MANOR / Memorial Drive  
PERMIT NUMBER: 12394

INSPECTION DATE:

Codes Used: NFPA 70, NEC 200, or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- |   |  |
|---|--|
| 1. Temp Sump Pump Connection <input type="checkbox"/> | 1. Electrical Pool Cover <input type="checkbox"/>      |
| 2. T-pole <input type="checkbox"/>                    | 2. Electrical Pool Final <input type="checkbox"/>      |
| 3. Ditch Cover <input type="checkbox"/>               | 1. Generator Ditch Cover <input type="checkbox"/>      |
| 4. Slab Cover <input type="checkbox"/>                | 2. Generator Electrical Final <input type="checkbox"/> |
| 5. Wall / Ceiling Cover <input type="checkbox"/>      | 1. Partial / See Comments <input type="checkbox"/>     |
| 6. TCI <input checked="" type="checkbox"/>            |  |
| 7. Meter Loop And Service <input type="checkbox"/>    |  |
| 8. Reconnect <input type="checkbox"/>                 |  |
| 9. Electrical Final <input type="checkbox"/>          |  |
| 10. Landscape Lighting Cover <input type="checkbox"/> |  |
| 11. Landscape Lighting Final <input type="checkbox"/> |  |



|            |                |
|------------|----------------|
| PASS       | <u>FAIL</u>    |
| DATE:      | <u>3-20-14</u> |
| TIME:      | <u>1:00</u>    |
| INSPECTOR: | <u>B</u>       |

CONTRACTOR/CALLER NAME: Method Wiring

CONTACT TEL/PGR/MOBILE: MAX Belen 281-900-2049

INSPECTOR COMMENTS:  
Install sealant, locknut between Meter  
& gutter, with bonding bushing  
Need larger gutter top  
Need more legs on ground bar

Reinspection fee required