

# REQUEST FOR ELECTRICAL INSPECTION

DATE: 4-11-14 TIME 10:15: AM / PM

JOB ADDRESS: 1 Fernham Park

PERMIT NUMBER: 13280

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2009, NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

PASS	<input checked="" type="checkbox"/> FAIL
DATE:	<u>4-11-14</u>
TIME:	<u>10:15</u>
INSPECTOR:	<u>[Signature]</u>

CONTRACTOR/CALLER NAME: Horizon Empire

CONTACT TEL/PGR/MOBILE: VICKIE 713-468-9606

INSPECTOR COMMENTS: Need Heavy Duty Ins-ure Cover on Construction T-poles



Reinspection fee required



# REQUEST FOR ELECTRICAL INSPECTION

DATE: 4-11-14 TIME 9:45: AM / PM

JOB ADDRESS: 650 Piney Point

PERMIT NUMBER: 13129

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005, NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- |   |  |
|---|--|
| 1. Temp Sump Pump Connection <input type="checkbox"/> | 1. Electrical Pool Cover <input type="checkbox"/>      |
| 2. T-pole <input type="checkbox"/>                    | 2. Electrical Pool Final <input type="checkbox"/>      |
| 3. Ditch Cover <input type="checkbox"/>               | 1. Generator Ditch Cover <input type="checkbox"/>      |
| 4. Slab Cover <input type="checkbox"/>                | 2. Generator Electrical Final <input type="checkbox"/> |
| 5. Wall / Ceiling Cover <input type="checkbox"/>      | 1. Partial / See Comments <input type="checkbox"/>     |
| 6. TCI <input checked="" type="checkbox"/>            |  |
| 7. Meter Loop And Service <input type="checkbox"/>    |  |
| 8. Reconnect <input type="checkbox"/>                 |  |
| 9. Electrical Final <input type="checkbox"/>          |  |
| 10. Landscape Lighting Cover <input type="checkbox"/> |  |
| 11. Landscape Lighting Final <input type="checkbox"/> |  |

PASS	<u>FAIL</u>
DATE:	<u>4-11-14</u>
TIME:	<u>9:45</u>
INSPECTOR:	<u>AB</u>

CONTRACTOR/CALLER NAME: Houston Empire

CONTACT TEL/PGR/MOBILE: Vickie 713-468-9606

INSPECTOR COMMENTS: Parallel wires must be 1/0 or larger  
Need to Replace Neutral wires from  
pole to Meter Can and From Meter  
Can to gutter.



Reinspection fee required

