

REQUEST FOR STRUCTURAL INSPECTION



CALL DATE: 04.28.2014 TIME 1:40 AM / PM
 PROPERTY ADDRESS: 1 Farnham Park
 INSPECTOR NAME: (Jeff Barva) # 13215

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass Fail Trash Anywhere on Property
- Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass Fail Dumpster full to the Lip & Needs to be Serviced
- Pass Fail Port-O-Can Door Facing Away From Street
- Pass Fail Port-O-Can Screened and/or Needs Maintenance
- Pass Fail Tree Protective Fencing Down
- Pass Fail Filter Fabric Fencing Down
- Pass Fail High Grass and/or Tall Weeds
- Pass Fail Overall Condition of Construction Site Good _____ Poor
_____ Verbal Warning _____ Site Cleaned at Insp. _____ City Citation Issued _____ City Notified

DATE: 04.28.2014 TIME 1:40 : _____ AM / PM

INSPECTION TYPE

- | | |
|--|---|
| <ul style="list-style-type: none"> 1. PRE-CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input checked="" type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|--|---|



CONTRACTOR/CALLER NAME: Boxer Properties / Hernandez (409) 39-9534

CONTACT TEL/PGR/MOBILE: _____

INSPECTOR COMMENTS: piers - new addition
(patio addition)
& foundation

PASS <u>PARTIAL</u> FAIL
DATE: <u>4/28/14</u>
TIME: <u>1:40 PM</u>
INSPECTOR: <u>[Signature]</u>

- pending eng. letter

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 04.28.2014 TIME : AM / PM

PROPERTY ADDRESS: Jeff Ybarra 455 Jan Kelly Ln

INSPECTOR NAME: (Mike Pelogian) PH 13038

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 04.28.2014 Monday TIME 3:00: PT AM / PM

INSPECTION TYPE

- | | |
|---|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|---|---|



CONTRACTOR/CALLER NAME: Tom Netek

CONTACT TEL/PGR/MOBILE: Thompson Custom Homes

INSPECTOR COMMENTS: 0(832) 509-6372-

new construction Windstorm clips -

PASS FAIL FAIL
DATE: <u>4/28/14</u>
TIME: <u>3:00</u>
INSPECTOR: <u>[Signature]</u>

Pending ENG LETTER.

-SHEATHING / CLIPS / STRAPS

REQUEST FOR ELECTRICAL INSPECTION

DATE: 4-28-14 TIME 9:00 AM/PM

JOB ADDRESS: 221 Millbrook

PERMIT NUMBER: 13131

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

<u>PASS</u>	FAIL
DATE: <u>4-28-14</u>	
TIME: <u>9:00</u>	
INSPECTOR: <u>JB</u>	

CONTRACTOR/CALLER NAME: Illuminescape

CONTACT TEL/PGR/MOBILE: Paul. 281-469-2000

INSPECTOR COMMENTS: _____

Reinspection fee required

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 04.28.2014 TIME : AM / PM

PROPERTY ADDRESS: 145 Radney Road

INSPECTOR NAME: Jeff Ybarra PH 13080 Pool House

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 04.28.2014 TIME : AM / PM
Minday

INSPECTION TYPE

- | | |
|--|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input checked="" type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|--|---|

Call 30min prior.
 Jeff (7) 899-4267 (c)



CONTRACTOR/CALLER NAME: Jeff Taylor

CONTACT TEL/PGR/MOBILE: Windham Builders

INSPECTOR COMMENTS: (7) 899-4267-

— pool house structural
pre sheet rock cover
OK TO COVER

PASS	FAIL
DATE: <u>4/28/14</u>	
TIME: <u>9:00 A</u>	
INSPECTOR: <u>JY</u>	

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 04.28.2014 TIME 11:57 : AM / PM
 PROPERTY ADDRESS: 11517 Paintree Circle
 INSPECTOR NAME: (Jeff Ybarra) PH 13195

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass Fail Trash Anywhere on Property
- Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass Fail Dumpster full to the Lip & Needs to be Serviced
- Pass Fail Port-O-Can Door Facing Away From Street
- Pass Fail Port-O-Can Screened and/or Needs Maintenance
- Pass Fail Tree Protective Fencing Down
- Pass Fail Filter Fabric Fencing Down
- Pass Fail High Grass and/or Tall Weeds
- Pass Fail Overall Condition of Construction Site Good _____ Poor
_____ Verbal Warning _____ Site Cleaned at Insp. _____ City Citation Issued _____ City Notified

DATE: 04.28.2014, Monday TIME 11:57 : AM / PM

INSPECTION TYPE

- | | |
|---|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|---|---|

POSTED
DACHOS

Texas Custom
Steven Scheil

CONTRACTOR/CALLER NAME: Steven Scheil

CONTACT TEL/PGR/MOBILE: (281) 752-2627

INSPECTOR COMMENTS: frame - new patio cover -
add out door kitchen.

PASS <input checked="" type="checkbox"/>	FAIL <input checked="" type="checkbox"/>
DATE: <u>4/28/14</u>	
TIME: <u>2:41</u>	
INSPECTOR: <u>[Signature]</u>	

- ① COMPLETE WINDSTRAPPING AT FIRE PLACE WALL AND WALL P TO THE RIGHT
- ② OBTAIN ENG. APPROVAL FOR HTP RAFFER/CEILING JOCK COMM.