

REQUEST FOR ELECTRICAL INSPECTION

DATE: 7-11-14 TIME _____ : AM / PM

JOB ADDRESS: 11519 DUNSINANE Lane

PERMIT NUMBER: 12721

INSPECTION DATE: _____

Codes Used: NFPA 70, NEC 2005 OF NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3) _____

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

<u>PASS</u>	FAIL
DATE: <u>7-14-14</u>	
TIME: _____	
INSPECTOR: <u>[Signature]</u>	

CONTRACTOR/CALLER NAME: Apche red Electric
CONTACT TEL/PGR/MOBILE: 705-832-274-2989

INSPECTOR COMMENTS: _____

NEED TO RELEASE TO Centrepoint

attn: Casandra

10:27 am 07-18-2014

[Signature]



Reinspection fee required

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 07.10.2014 TIME : AM / PM

PROPERTY ADDRESS: 202 Millbrook

INSPECTOR NAME: (Jeff Ybarra) #13419

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 07.14.2014 ~~07.10.2014~~ TIME : AM / PM
Friday Monday

INSPECTION TYPE

- | | |
|--|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input checked="" type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|--|---|

CONTRACTOR/CALLER NAME: Yigael Kass

CONTACT TEL/PGR/MOBILE: Watermark Builders

INSPECTOR COMMENTS: (713) 291-9502 -

foundation -
- check clearance to sides and fittings of beams
- eng. approval on #14
- re entrant bars

PASS	FAIL
DATE: <u>7/14/14</u>	
TIME: <u>11:45 am</u>	
INSPECTOR: <u>[Signature]</u>	

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 07.14.2014 TIME : AM / PM
 PROPERTY ADDRESS: 3576 Piney Point Rd
 INSPECTOR NAME: (Jeff 4barr) PH 13230

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 07.14.2014 / Monday TIME : AM / PM

INSPECTION TYPE

- | | |
|--|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input checked="" type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|--|---|



CONTRACTOR/CALLER NAME: Chris Thelen
 CONTACT TEL/PGR/MOBILE: Thompson Custom Homes
 INSPECTOR COMMENTS: (832)250-1291 (C)
Windstorm clip & strap -
inspection

PASS	FAIL
DATE: <u>7/14/14</u>	
TIME: <u>11:55 AM</u>	
INSPECTOR: <u>[Signature]</u>	

REQUEST FOR ELECTRICAL INSPECTION

DATE: 7-14-14 TIME 10:35 AM / PM

JOB ADDRESS: 8 Tokeneke

PERMIT NUMBER: 13511

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- | | |
|--|--|
| 1. Temp Sump Pump Connection <input checked="" type="checkbox"/> | 1. Electrical Pool Cover <input type="checkbox"/> |
| 2. T-pole <input type="checkbox"/> | 2. Electrical Pool Final <input type="checkbox"/> |
| 3. Ditch Cover <input type="checkbox"/> | 1. Generator Ditch Cover <input type="checkbox"/> |
| 4. Slab Cover <input type="checkbox"/> | 2. Generator Electrical Final <input type="checkbox"/> |
| 5. Wall / Ceiling Cover <input type="checkbox"/> | 1. Partial / See Comments <input type="checkbox"/> |
| 6. TCI <input type="checkbox"/> | |
| 7. Meter Loop And Service <input type="checkbox"/> | |
| 8. Reconnect <input type="checkbox"/> | |
| 9. Electrical Final <input type="checkbox"/> | |
| 10. Landscape Lighting Cover <input type="checkbox"/> | |
| 11. Landscape Lighting Final <input type="checkbox"/> | |



PASS	<u>FAIL</u>
DATE:	<u>7-14-14</u>
TIME:	<u>10:35</u>
INSPECTOR:	<u>JB</u>

CONTRACTOR/CALLER NAME: Hovster Empire Electric

CONTACT TEL/PGR/MOBILE: Joe 713-468-9606

INSPECTOR COMMENTS: Sump Pump needs to be on GFI

Reinspection fee required