

REQUEST FOR ELECTRICAL INSPECTION

DATE: 9-18-14 TIME 10:15 AM / PM

JOB ADDRESS: 11319 Inmestown

PERMIT NUMBER: 11884

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2009 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- | | |
|---|--|
| 1. Temp Sump Pump Connection <input type="checkbox"/> | 1. Electrical Pool Cover <input type="checkbox"/> |
| 2. T-pole <input type="checkbox"/> | 2. Electrical Pool Final <input type="checkbox"/> |
| 3. Ditch Cover <input type="checkbox"/> | 1. Generator Ditch Cover <input type="checkbox"/> |
| 4. Slab Cover <input type="checkbox"/> | 2. Generator Electrical Final <input type="checkbox"/> |
| 5. Wall / Ceiling Cover <input type="checkbox"/> | 1. Partial / See Comments <input type="checkbox"/> |
| 6. TCI <input type="checkbox"/> | |
| 7. Meter Loop And Service <input type="checkbox"/> | |
| 8. Reconnect <input type="checkbox"/> | |
| 9. Electrical Final <input checked="" type="checkbox"/> | |
| 10. Landscape Lighting Cover <input type="checkbox"/> | |
| 11. Landscape Lighting Final <input type="checkbox"/> | |

PASS	<u>FAIL</u>
DATE:	<u>9-18-14</u>
TIME:	<u>10:15</u>
INSPECTOR:	<u>JB</u>

CONTRACTOR/CALLER NAME: E Diamond Electric

CONTACT TEL/PGR/MOBILE: Antonia 832-526-9058

INSPECTOR COMMENTS:

All garage plugs must be GFI protected
A/C Disconnects cannot be behind A/C unit 3' Clear
2nd Kitchen - plugs need to be GFI protected.
Need to Add plugs in Kitchen w/ cabinets for
code spacing
All fixtures must be grounded
Need Spark Ring in 1st Bath on Vanity
(CK All plugs that may need spark rings)
Need In-Use Covers on Outside plugs
balcony back porch.
Need to label panels upstairs
CK A/C Breaker Sizes
label Disconnects, panels

Reinspection fee required

