

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 09.25.2014 TIME: _____ : _____ AM / PM
 PROPERTY ADDRESS: 202 Millbrook Street
 INSPECTOR NAME: (Jeff Urbana) PH 13149

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good _____ Poor
- _____ Verbal Warning _____ Site Cleaned at Insp. _____ City Citation Issued _____ City Notified

DATE: 09.26.2014 / Friday TIME: _____ : _____ AM / PM

INSPECTION TYPE

- | | |
|--|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input checked="" type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|--|---|

CONTRACTOR/CALLER NAME: Yigal Kass

CONTACT TEL/PGR/MOBILE: Watermark Builders

INSPECTOR COMMENTS: wind storm (requesting afternoon)

PASS <u>PARTIAL</u> FAIL
DATE: <u>9/26/14</u>
TIME: <u>10:58 am</u>
INSPECTOR: <u>[Signature]</u>

- clips/straps at roof only

1/320 to 1

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 09.25.2014 TIME: _____ : _____ AM / PM
 PROPERTY ADDRESS: 40 Still forest St.
 INSPECTOR NAME: (Jeff Ybama) P# 12780

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site ✓ Good _____ Poor
- _____ Verbal Warning _____ Site Cleaned at Insp. _____ City Citation Issued _____ City Notified

DATE: 09.26.2014 Friday TIME: _____ : _____ AM / PM

INSPECTION TYPE

- | | |
|--|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input checked="" type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|--|---|

CONTRACTOR/CALLER NAME: Mike Kilani (832) 877-9098
 CONTACT TEL/PGR/MOBILE: Tanglewood Builders

PASS	FAIL
DATE: <u>9/26/14</u>	
TIME: <u>10:47</u>	
INSPECTOR: <u>[Signature]</u>	

INSPECTOR COMMENTS: frame cover
Still NO-
 * (NO fire sprinkler cover w/ chuck Erlund)
 * NO, engineer letters in regards to framing, stairs & height - Still NO-height certificate foundation & piers for main house & tennis Ct. acc. struct.
 ✓ Fire dept cover (OK)
 * Re-inspection fee required - 2 x \$50. - \$100. -
still need to complete fireblockins (typical)