

REQUEST FOR ELECTRICAL INSPECTION

DATE: 9-29-14 TIME: 10:30 AM / PM

JOB ADDRESS: 570 BANECROSS

PERMIT NUMBER: 13746

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

PASS

FAIL

DATE: 9-29-14

TIME: 10:30

INSPECTOR: JB

CONTRACTOR/CALLER NAME: Custom Electric Design

CONTACT TEL/PGR/MOBILE: Johnny 281-723-5431

INSPECTOR COMMENTS: Pool bond wire needs to be continuous
Need to see lights ~~to~~ pulled in and sealed.
to look at later.

Reinspection fee required

REQUEST FOR ELECTRICAL INSPECTION

DATE: 9-29-14 TIME: 11:15 AM / PM

JOB ADDRESS: 11314 Treis Bee

PERMIT NUMBER: 13360

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- | | |
|---|--|
| 1. Temp Sump Pump Connection <input type="checkbox"/> | 1. Electrical Pool Cover <input type="checkbox"/> |
| 2. T-pole <input type="checkbox"/> | 2. Electrical Pool Final <input type="checkbox"/> |
| 3. Ditch Cover <input type="checkbox"/> | 1. Generator Ditch Cover <input type="checkbox"/> |
| 4. Slab Cover <input type="checkbox"/> | 2. Generator Electrical Final <input type="checkbox"/> |
| 5. Wall / Ceiling Cover <input type="checkbox"/> | 1. Partial / See Comments <input type="checkbox"/> |
| 6. TCI <input checked="" type="checkbox"/> | |
| 7. Meter Loop And Service <input type="checkbox"/> | |
| 8. Reconnect <input type="checkbox"/> | |
| 9. Electrical Final <input type="checkbox"/> | |
| 10. Landscape Lighting Cover <input type="checkbox"/> | |
| 11. Landscape Lighting Final <input type="checkbox"/> | |

<u>PASS</u>	FAIL
DATE: <u>9-29-14</u>	
TIME: <u>11:15</u>	
INSPECTOR: <u>B</u>	

CONTRACTOR/CALLER NAME: Electrical Works of Houston

CONTACT TEL/PGR/MOBILE: Rick Curry 713-476-0429

INSPECTOR COMMENTS: Need to Release to Centekpoint

Reinspection fee required

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 09.29.2014 TIME _____ : _____ AM / PM

PROPERTY ADDRESS: 7 Pine Tree Ln

INSPECTOR NAME: PH 1-3002

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 09.29.2014, Monday TIME _____ : _____ AM / PM

INSPECTION TYPE


- | | |
|---|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <p><i>requesting afternoon</i></p> <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input checked="" type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|---|---|

CONTRACTOR/CALLER NAME: Leathly Norman

CONTACT TEL/PGR/MOBILE: Integrity Concrete

INSPECTOR COMMENTS: Driveway / Flatwork forms.

PASS <input checked="" type="checkbox"/>	FAIL <input type="checkbox"/>
DATE: <u>9/29-14</u>	
TIME: <u>4:00</u>	
INSPECTOR: <u>MP</u>	



REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 09.29.14 TIME : AM / PM

PROPERTY ADDRESS: 338 Tynebridge Ln

INSPECTOR NAME: (Mike Peloguin) #13582

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 09.29.14 ^{Monday} TIME : AM / PM

INSPECTION TYPE

- | | |
|---|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. <u>PIERS</u> <input checked="" type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|---|---|

CONTRACTOR/CALLER NAME: 338 Ltd, LLC

CONTACT TEL/PGR/MOBILE: Mark Harvie

INSPECTOR COMMENTS: (281) 850-7120

fence piers

PASS	FAIL
DATE: <u>9-29-14</u>	
TIME: <u>10:00</u>	
INSPECTOR: <u>MP</u>	