

REQUEST FOR **ELECTRICAL** INSPECTION

DATE: 11.18.2014 TIME: \_\_\_\_\_ : AM / PM

JOB ADDRESS: 3 Oaklawn Drive

PERMIT NUMBER: P# 13799

INSPECTION DATE: 11.19.14 *Wednesday*

Codes Used: IPC 2009 NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: ~~1) Jason Bienek~~ ~~2) Dave Whittaker~~ ~~3) \_\_\_\_\_~~ Chuck Erhlind

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

*plumbing gas*

PASS	<u>FAIL</u>
DATE:	<u>11-19-14</u>
TIME:	<u>12:40</u>
INSPECTOR:	<u>4/18</u>

CONTRACTOR/CALLER NAME: Ramiro Ramirez (832) 692-6899

CONTACT TEL/PGR/MOBILE: w/ Kalin Plumbing Co.

INSPECTOR COMMENTS: plumbing gas for a pool

~~FAIL~~ WOODING GAGE

~~FAIL~~ PIPE under concrete

Must have  
Wizshram Gage

Reinspection fee required