

REQUEST FOR ELECTRICAL INSPECTION

DATE: 1-9-13 TIME 11:00 AM/PM

JOB ADDRESS: 1117 Beinhorn

PERMIT NUMBER: 10936

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

PASS	FAIL
DATE:	<u>1-9-13</u>
TIME:	<u>11:00</u>
INSPECTOR:	<u>AB</u>

CONTRACTOR/CALLER NAME: Oshel Electric

CONTACT TEL/PGR/MOBILE: Oscar Beltrame

INSPECTOR COMMENTS: _____

All Panel lids must be on panels
* All panel lid openings must be filled



Reinspection fee required