

REQUEST FOR ELECTRICAL INSPECTION

DATE: 1-9-13 TIME 11:00 AM / PM

JOB ADDRESS: 1117 Beinhorn

PERMIT NUMBER: 10936

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- | | | | |
|------------------------------|-------------------------------------|-------------------------------|--------------------------|
| 1. Temp Sump Pump Connection | <input type="checkbox"/> | 1. Electrical Pool Cover | <input type="checkbox"/> |
| 2. T-pole | <input type="checkbox"/> | 2. Electrical Pool Final | <input type="checkbox"/> |
| 3. Ditch Cover | <input type="checkbox"/> | 1. Generator Ditch Cover | <input type="checkbox"/> |
| 4. Slab Cover | <input type="checkbox"/> | 2. Generator Electrical Final | <input type="checkbox"/> |
| 5. Wall / Ceiling Cover | <input type="checkbox"/> | 1. Partial / See Comments | <input type="checkbox"/> |
| 6. TCI | <input checked="" type="checkbox"/> | | |
| 7. Meter Loop And Service | <input type="checkbox"/> | | |
| 8. Reconnect | <input type="checkbox"/> | | |
| 9. Electrical Final | <input type="checkbox"/> | | |
| 10. Landscape Lighting Cover | <input type="checkbox"/> | | |
| 11. Landscape Lighting Final | <input type="checkbox"/> | | |

PASS	FAIL
DATE:	<u>1-9-13</u>
TIME:	<u>11:00</u>
INSPECTOR:	<u>AB</u>

CONTRACTOR/CALLER NAME: Oshel Electric

CONTACT TEL/PGR/MOBILE: Oscar Beltrame

INSPECTOR COMMENTS: _____

All panel lids must be on panels
* All panel lid openings must be filled



Reinspection fee required