

# REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 01.21, 2013 TIME: \_\_\_\_\_ : \_\_\_\_\_ AM / PM  
 PROPERTY ADDRESS: 11519 Dunsinane  
 INSPECTOR NAME: Cam Moran Tree Protection Fencing

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass  Fail Trash Anywhere on Property
- Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass  Fail Dumpster full to the Lip & Needs to be Serviced
- Pass  Fail Port-O-Can Door Facing Away From Street
- Pass  Fail Port-O-Can Screened and/or Needs Maintenance
- Pass  Fail Tree Protective Fencing Down
- Pass  Fail Filter Fabric Fencing Down
- Pass  Fail High Grass and/or Tall Weeds
- Pass  Fail Overall Condition of Construction Site Good Poor  
Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 01.22.2013 <sup>Tuesday</sup> TIME: \_\_\_\_\_ : \_\_\_\_\_ AM / PM

## INSPECTION TYPE

- |  |  |  |
|--|--|--|
| <ul style="list-style-type: none"> <li>1. PRE CONSTRUCTION SITE <input type="checkbox"/></li> <li>2. PIERS <input type="checkbox"/></li> <li>3. FOUNDATION STEEL <input type="checkbox"/></li> <li>4. RIDGE HEIGHT <input type="checkbox"/></li> <li>5. HURRICANE TIES <input checked="" type="checkbox"/></li> <li>6. STUCCO LATHE/BRICK TIES <input type="checkbox"/></li> <li>7. FRAMING / FRAMING COVER <input type="checkbox"/></li> <li>8. BUILDING FINAL <input type="checkbox"/></li> <li>9. TREE FINAL <input type="checkbox"/></li> <li>10. ROOF Final/ DEMO FINAL <input type="checkbox"/></li> <li>11. Generator Steel <input type="checkbox"/></li> <li>12. Generator Final <input type="checkbox"/></li> </ul> | <p style="font-size: 2em; color: blue;">(281) 347-4399 (F)</p> | <ul style="list-style-type: none"> <li>1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/></li> <li>2. POOL STEEL <input type="checkbox"/></li> <li>3. POOL DECK/PATIO STEEL <input type="checkbox"/></li> <li>4. POOL BARRIER <input type="checkbox"/></li> <li>4. POOL FINAL <input type="checkbox"/></li> <li>1. FENCE POST HOLE <input type="checkbox"/></li> <li>2. FENCE FINAL <input type="checkbox"/></li> <li>1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/></li> <li>2. DRIVEWAY FINAL <input type="checkbox"/></li> <li>3. OTHER <input type="checkbox"/></li> <li>4. TRENCH <input type="checkbox"/></li> <li>5. TEMP FENCING <input checked="" type="checkbox"/></li> </ul> |
|--|--|--|

CONTRACTOR/CALLER NAME: Cam Horn  
 CONTACT TEL/PGR/MOBILE: Horn Building Co;  
(832) (681) - 3151  
 INSPECTOR COMMENTS: Tree Protection Fencing (NC)

PASS <input checked="" type="checkbox"/>	FAIL
DATE: <u>1-22-13</u>	
TIME: <u>11:30</u>	
INSPECTOR: <u>CMORAN</u>	

tree fence (4') & signs in place  
cm  
put ticket in mail box

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 01.21.2013 TIME: : AM / PM  
PROPERTY ADDRESS: 243 Piney Point Rd  
INSPECTOR NAME: # 12183

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass Fail Trash Anywhere on Property
- Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass Fail Dumpster full to the Lip & Needs to be Serviced
- Pass Fail Port-O-Can Door Facing Away From Street
- Pass Fail Port-O-Can Screened and/or Needs Maintenance
- Pass Fail Tree Protective Fencing Down
- Pass Fail Filter Fabric Fencing Down
- Pass Fail High Grass and/or Tall Weeds
- Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 01.22.2013 Tuesday TIME: : AM / PM  
(Cory Moran)

INSPECTION TYPE

- 1. PRE CONSTRUCTION SITE
- 2. PIERS
- 3. FOUNDATION STEEL
- 4. RIDGE HEIGHT
- 5. HURRICANE TIES
- 6. STUCCO LATHE/BRICK TIES
- 7. FRAMING / FRAMING COVER
- 8. BUILDING FINAL
- 9. TREE FINAL
- 10. ROOF Final/ DEMO FINAL
- 11. Generator Steel
- 12. Generator Final
- 1. POOL STAKE OUT/POOL SET-UP
- 2. POOL STEEL
- 3. POOL DECK/PATIO STEEL
- 4. POOL BARRIER
- 4. POOL FINAL
- 1. FENCE POST HOLE
- 2. FENCE FINAL
- 1. DRIVEWAY/FLATWORK FORMS
- 2. DRIVEWAY FINAL
- 3. OTHER
- 4. TRENCH
- 5. TEMP FENCING



CONTRACTOR/CALLER NAME: Jared D.

CONTACT TEL/PGR/MOBILE: Eden Project

INSPECTOR COMMENTS: (832) 405-8155

(trench - for irrigation)

PASS	✓	FAIL
DATE:	1-22-13	
TIME:	12 PM	
INSPECTOR:	C Moran	

on roots over 1 inch cut

put ticket in mail box

# REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 01.21.2013 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM

PROPERTY ADDRESS: 334 Tynebrook

INSPECTOR NAME: (W. Applegate) P# 12174  
George Sanders

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
  - Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
  - Pass  Fail Trash Anywhere on Property
  - Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
  - Pass  Fail Dumpster full to the Lip & Needs to be Serviced
  - Pass  Fail Port-O-Can Door Facing Away From Street
  - Pass  Fail Port-O-Can Screened and/or Needs Maintenance
  - Pass  Fail Tree Protective Fencing Down
  - Pass  Fail Filter Fabric Fencing Down
  - Pass  Fail High Grass and/or Tall Weeds
  - Pass  Fail Overall Condition of Construction Site Good \_\_\_\_\_ Poor
- \_\_\_\_\_ Verbal Warning \_\_\_\_\_ Site Cleaned at Insp. \_\_\_\_\_ City Citation Issued \_\_\_\_\_ City Notified

DATE: 01.22.2013 Tuesday TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM

## INSPECTION TYPE

- |   |  |
|---|--|
| <ul style="list-style-type: none"> <li>1. PRE CONSTRUCTION SITE <input type="checkbox"/></li> <li>2. PIERS <input type="checkbox"/></li> <li>3. FOUNDATION STEEL <input type="checkbox"/></li> <li>4. RIDGE HEIGHT <input type="checkbox"/></li> <li>5. HURRICANE TIES <input type="checkbox"/></li> <li>6. STUCCO LATHE/BRICK TIES <input type="checkbox"/></li> <li>7. FRAMING / FRAMING COVER <input type="checkbox"/></li> <li>8. BUILDING FINAL <input type="checkbox"/></li> <li>9. TREE FINAL <input type="checkbox"/></li> <li>10. ROOF Final/ DEMO FINAL <input type="checkbox"/></li> <li>11. Generator Steel <input type="checkbox"/></li> <li>12. Generator Final <input type="checkbox"/></li> </ul> | <ul style="list-style-type: none"> <li>1. POOL STAKE OUT/POOL SET-UP <input checked="" type="checkbox"/></li> <li>2. POOL STEEL <input type="checkbox"/></li> <li>3. POOL DECK/PATIO STEEL <input type="checkbox"/></li> <li>4. POOL BARRIER <input type="checkbox"/></li> <li>4. POOL FINAL <input type="checkbox"/></li> <li>1. FENCE POST HOLE <input type="checkbox"/></li> <li>2. FENCE FINAL <input type="checkbox"/></li> <li>1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/></li> <li>2. DRIVEWAY FINAL <input type="checkbox"/></li> <li>3. OTHER <input type="checkbox"/></li> <li>4. TRENCH <input type="checkbox"/></li> <li>5. TEMP FENCING <input type="checkbox"/></li> </ul> |
|---|--|
- (7/13) 6416-9013 (F)

CONTRACTOR/CALLER NAME: Lothar Hofbauer

CONTACT TEL/PGR/MOBILE: element Garden

INSPECTOR COMMENTS: (832) 858-0242

pool stake out

PASS <input checked="" type="checkbox"/>	FAIL <input type="checkbox"/>
DATE: <u>1/22/13</u>	
TIME: <u>12:30</u>	
INSPECTOR: <u>ASJ</u>	

ASJ

# REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 01.21.2013 TIME: \_\_\_\_\_ : \_\_\_\_\_ AM / PM

JOB ADDRESS: 1333 Iris Lee Ln

PERMIT NUMBER: P # 12182

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
  - Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
  - Pass  Fail Trash Anywhere on Property
  - Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
  - Pass  Fail Dumpster full to the Lip & Needs to be Serviced
  - Pass  Fail Port-O-Can Door Facing Away From Street
  - Pass  Fail Port-O-Can Screened and/or Needs Maintenance
  - Pass  Fail Tree Protective Fencing Down
  - Pass  Fail Filter Fabric Fencing Down
  - Pass  Fail High Grass and/or Tall Weeds
  - Pass  Fail Overall Condition of Construction Site Good \_\_\_\_\_ Poor
- \_\_\_ Verbal Warning \_\_\_ Site Cleaned at Insp. \_\_\_ City Citation Issued \_\_\_ City Notified

INSPECTOR: George Sanders

Tuesday

INSPECTION DATE: 01.22.2013

PLUMBING	MECHANICAL
----------	------------

- |  |   |
|--|---|
| <ul style="list-style-type: none"> <li>1. Water line <input type="checkbox"/></li> <li>2. Rough In <input type="checkbox"/></li> <li>3. Top Out <input type="checkbox"/></li> <li>4. Shower Pan <input type="checkbox"/></li> <li>5. Sewer Line <input type="checkbox"/></li> <li>6. WC Flange <input type="checkbox"/></li> <li>7. GTO <input type="checkbox"/></li> <li>8. Plumbing Final <input type="checkbox"/></li> <li>9. Pool Drainage <input type="checkbox"/></li> <li>10. Site Drainage <input type="checkbox"/></li> <li>11. Irrigation Final <input checked="" type="checkbox"/></li> <li>12. Other <input type="checkbox"/></li> </ul> | <p style="font-size: 2em; opacity: 0.5;">(913) 646-1801 (F)</p> |
|--|---|

- 1. Vent Hood
- 2. Rough/cover
- 3. Mech Final
- 4. Water Heater Final
- 5. Fire Sprinkler cover (need MVFD approval)
- 6. Fire Sprinkler Final

PASS <input checked="" type="checkbox"/>	FAIL <input type="checkbox"/>
DATE: <u>1/22/13</u>	
TIME: <u>1:30</u>	
INSPECTOR: <u>[Signature]</u>	

CONTRACTOR/CALLER NAME: JLA Plumbing Company

CONTACT TEL/PGR/MOBILE: Oscar Davila (913) 646-1800

INSPECTOR COMMENTS: Plumbing ground

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

1/22/13  
1:30

# REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 01.21.2013 TIME: \_\_\_\_\_ : \_\_\_\_\_ AM / PM  
 JOB ADDRESS: 11333 Iris Ln W  
 PERMIT NUMBER: P# 12182

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass  Fail Trash Anywhere on Property
- Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass  Fail Dumpster full to the Lip & Needs to be Serviced
- Pass  Fail Port-O-Can Door Facing Away From Street
- Pass  Fail Port-O-Can Screened and/or Needs Maintenance
- Pass  Fail Tree Protective Fencing Down
- Pass  Fail Filter Fabric Fencing Down
- Pass  Fail High Grass and/or Tall Weeds
- Pass  Fail Overall Condition of Construction Site Good Poor  
Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

INSPECTOR: George Sanders INSPECTION DATE: Tuesday  
01.22.  
2013

PLUMBING	MECHANICAL
1. Water line <input type="checkbox"/>	1. Vent Hood <input type="checkbox"/>
2. Rough In <input type="checkbox"/>	2. Rough/cover <input type="checkbox"/>
3. Top Out <input type="checkbox"/>	3. Mech Final <input type="checkbox"/>
4. Shower Pan <input type="checkbox"/>	4. Water Heater Final <input type="checkbox"/>
5. Sewer Line <input checked="" type="checkbox"/>	5. Fire Sprinkler cover <input type="checkbox"/> <small>(need MVFD approval)</small>
6. WC Flange <input type="checkbox"/>	6. Fire Sprinkler Final <input type="checkbox"/>
7. GTO <input type="checkbox"/>	
8. Plumbing Final <input type="checkbox"/>	
9. Pool Drainage <input type="checkbox"/>	
10. Site Drainage <input type="checkbox"/>	
11. Irrigation Final <input type="checkbox"/>	
12. Other <input type="checkbox"/>	

(713) 640-1801 (F)

POSTED

<b>PASS</b> <input checked="" type="checkbox"/>	<b>FAIL</b>
DATE: <u>1/22/13</u>	
TIME: <u>1:30</u>	
INSPECTOR: <u>George Sanders</u>	

(New construction)  
 CONTRACTOR/CALLER NAME: Oscar Davila (713) 640-1800  
 CONTACT TEL/PGR/MOBILE: JLA Plumbing Co.  
 INSPECTOR COMMENTS: plumbing sewer line

ack

# REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 01.21.2013 TIME: \_\_\_\_\_ : \_\_\_\_\_ AM / PM  
 PROPERTY ADDRESS: 35 Stillforest St.  
 INSPECTOR NAME: (George Sanders) PH 12117

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass  Fail Trash Anywhere on Property
- Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass  Fail Dumpster full to the Lip & Needs to be Serviced
- Pass  Fail Port-O-Can Door Facing Away From Street
- Pass  Fail Port-O-Can Screened and/or Needs Maintenance
- Pass  Fail Tree Protective Fencing Down
- Pass  Fail Filter Fabric Fencing Down
- Pass  Fail High Grass and/or Tall Weeds
- Pass  Fail Overall Condition of Construction Site Good \_\_\_\_\_ Poor
- \_\_\_\_\_ Verbal Warning \_\_\_\_\_ Site Cleaned at Insp. \_\_\_\_\_ City Citation Issued \_\_\_\_\_ City Notified

DATE: 01.22.2013 *Tuesday* TIME: \_\_\_\_\_ : \_\_\_\_\_ AM / PM

## INSPECTION TYPE

- |   |   |   |
|---|---|---|
| <ul style="list-style-type: none"> <li>1. PRE CONSTRUCTION SITE <input type="checkbox"/></li> <li>2. PIERS <input type="checkbox"/></li> <li>3. FOUNDATION STEEL <input type="checkbox"/></li> <li>4. RIDGE HEIGHT <input type="checkbox"/></li> <li>5. HURRICANE TIES <input type="checkbox"/></li> <li>6. STUCCO LATHE/BRICK TIES <input type="checkbox"/></li> <li>7. FRAMING / FRAMING COVER <input type="checkbox"/></li> <li>8. BUILDING FINAL <input type="checkbox"/></li> <li>9. TREE FINAL <input type="checkbox"/></li> <li>10. ROOF Final/ DEMO FINAL <input type="checkbox"/></li> <li>11. Generator Steel <input type="checkbox"/></li> <li>12. Generator Final <input type="checkbox"/></li> </ul> | <p><i>(281) 558-9139 (+)</i><br/><i>(late afternoon)</i><br/><i>(713) 402-9922 cell</i></p> | <ul style="list-style-type: none"> <li>1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/></li> <li>2. POOL STEEL <input type="checkbox"/></li> <li>3. POOL DECK/PATIO STEEL <input type="checkbox"/></li> <li>4. POOL BARRIER <input type="checkbox"/></li> <li>4. POOL FINAL <input type="checkbox"/></li> <li>1. FENCE POST HOLE <input type="checkbox"/></li> <li>2. FENCE FINAL <input type="checkbox"/></li> <li>1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/></li> <li>2. DRIVEWAY FINAL <input type="checkbox"/></li> <li>3. OTHER <input type="checkbox"/></li> <li>4. TRENCH <input type="checkbox"/></li> <li>5. TEMP FENCING <input type="checkbox"/></li> </ul> |
|---|---|---|

CONTRACTOR/CALLER NAME: Call Truman

CONTACT TEL/PGR/MOBILE: March Pools

INSPECTOR COMMENTS: pool piers (18)

*NOT READY*

PASS	<b>FAIL</b> <input checked="" type="checkbox"/>
DATE: <u>1/22/13</u>	
TIME: <u>1:40</u>	
INSPECTOR: <u>[Signature]</u>	

REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 01.21.2013 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM

JOB ADDRESS: 11110 Wicklway

PERMIT NUMBER: P# 11982

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass  Fail Trash Anywhere on Property
- Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass  Fail Dumpster full to the Lip & Needs to be Serviced
- Pass  Fail Port-O-Can Door Facing Away From Street
- Pass  Fail Port-O-Can Screened and/or Needs Maintenance
- Pass  Fail Tree Protective Fencing Down
- Pass  Fail Filter Fabric Fencing Down
- Pass  Fail High Grass and/or Tall Weeds
- Pass  Fail Overall Condition of Construction Site Good  Poor
- Verbal Warning  Site Cleaned at Insp.  City Citation Issued  City Notified

Tuesday

INSPECTOR : George Sanders

INSPECTION DATE: 01.22.2013

PLUMBING MECHANICAL

- 1. Water line
- 2. Rough In
- 3. Top Out
- 4. Shower Pan
- 5. Sewer Line
- 6. WC Flange
- 7. GTO
- 8. Plumbing Final
- 9. Pool Drainage
- 10 Site Drainage
- 11. Irrigation Final
- 12. Other

(281)458-4025(f)

- 1. Vent Hood
- 2. Rough/cover
- 3. Mech Final
- 4. Water Heater Final
- 5. Fire Sprinkler cover   
(need MVFD approval)
- 6. Fire Sprinkler Final



PASS <input checked="" type="checkbox"/>	FAIL
DATE: <u>1/21/13</u>	
TIME: <u>11:15</u>	
INSPECTOR: <u>G. Sanders</u>	

CONTRACTOR/CALLER NAME: Steve Alberle @ (281) 458-5911

CONTACT TEL/PGR/MOBILE: Alberle Plumbing Company

INSPECTOR COMMENTS: Shower pan & tub

4 BATHS 2-TUB OK

# REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 01.21.2013 TIME: \_\_\_\_\_ : \_\_\_\_\_ AM / PM  
 JOB ADDRESS: 11095 Memorial Drive  
# 12145  
 PERMIT NUMBER: \_\_\_\_\_

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass  Fail Trash Anywhere on Property
- Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass  Fail Dumpster full to the Lip & Needs to be Serviced
- Pass  Fail Port-O-Can Door Facing Away From Street
- Pass  Fail Port-O-Can Screened and/or Needs Maintenance
- Pass  Fail Tree Protective Fencing Down
- Pass  Fail Filter Fabric Fencing Down
- Pass  Fail High Grass and/or Tall Weeds
- Pass  Fail Overall Condition of Construction Site Good Poor  
Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

INSPECTOR: George Sanders INSPECTION DATE: 01.22  
2013

PLUMBING	MECHANICAL
1. Water line <input type="checkbox"/>	1. Vent Hood <input type="checkbox"/>
2. Rough In <input type="checkbox"/>	2. Rough/cover <input type="checkbox"/>
3. Top Out <input type="checkbox"/>	3. Mech Final <input checked="" type="checkbox"/>
4. Shower Pan <input type="checkbox"/>	4. Water Heater Final <input type="checkbox"/>
5. Sewer Line <input type="checkbox"/>	5. Fire Sprinkler cover (need MVFD approval) <input type="checkbox"/>
6. WC Flange <input type="checkbox"/>	6. Fire Sprinkler Final <input type="checkbox"/>
7. GTO <input type="checkbox"/>	
8. Plumbing Final <input type="checkbox"/>	
9. Pool Drainage <input type="checkbox"/>	
10. Site Drainage <input type="checkbox"/>	
11. Irrigation Final <input type="checkbox"/>	
12. Other <input type="checkbox"/>	



PASS	<b>FAIL</b>
DATE: <u>1/22/13</u>	
TIME: <u>12:00</u>	
INSPECTOR: <u>[Signature]</u>	

CONTRACTOR/CALLER NAME: Chad Morrow  
 CONTACT TEL/PGR/MOBILE: Cool Guys  
(832) 482-8921

INSPECTOR COMMENTS: Mech Final

Note Ⓟ +1  
ID Condensers + Disconnects + Breakers Verify Max Breaker - STRAP Conduit - Also Attic  
Attic Walk Ways + SERVICE AREAS DO NOT COMPLY  
 1.) 1" INSULATION @ WINE ROOM COOLER / AC LINE  
Also all lines in attic  
 2.) LIGHTING @ UNITS REQUIRED  
 3.) ID CONDENSERS - AIR HANDLERS + BREAKERS  
 4.) INSTALL PAN CUTOFF SWITCHES  
 5.) INSTALL SEDIMENT TRAPS AT GAS