

REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-11-13 TIME 1:00: AM / PM

JOB ADDRESS: 218 Blalock

PERMIT NUMBER: 12230

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005, ~~NEC 2011~~

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

1-936-
fax. 295-
1764



PASS	FAIL
DATE:	<u>2-11-13</u>
TIME:	<u>1:00</u>
INSPECTOR:	<u>JB</u>

CONTRACTOR/CALLER NAME: Woods Electric

CONTACT TEL/PGR/MOBILE: MIKE BAXTER 832-260-6476

INSPECTOR COMMENTS:

Need HEAVY Duty IN USE covers
on T-Poles.

Reinspection fee required