

# REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 02.11.2013 TIME: \_\_\_\_\_ : \_\_\_\_\_ AM / PM  
 PROPERTY ADDRESS: 1126 Meadowick  
 INSPECTOR NAME: (Mike Peloguin) P# 12061

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
  - Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
  - Pass  Fail Trash Anywhere on Property
  - Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
  - Pass  Fail Dumpster full to the Lip & Needs to be Serviced
  - Pass  Fail Port-O-Can Door Facing Away From Street
  - Pass  Fail Port-O-Can Screened and/or Needs Maintenance
  - Pass  Fail Tree Protective Fencing Down
  - Pass  Fail Filter Fabric Fencing Down
  - Pass  Fail High Grass and/or Tall Weeds
  - Pass  Fail Overall Condition of Construction Site Good  Poor
- Verbal Warning  Site Cleaned at Insp.  City Citation Issued  City Notified

~~THURSDAY~~  
**WEDNESDAY**

DATE: 02.13.2013 TIME: \_\_\_\_\_ : \_\_\_\_\_ AM / PM

## INSPECTION TYPE

- |  |   |  |  |
|--|---|--|--|
| <ul style="list-style-type: none"> <li>1. PRE CONSTRUCTION SITE <input type="checkbox"/></li> <li>2. PIERS <input type="checkbox"/></li> <li>3. FOUNDATION STEEL <input checked="" type="checkbox"/></li> <li>4. RIDGE HEIGHT <input type="checkbox"/></li> <li>5. HURRICANE TIES <input type="checkbox"/></li> <li>6. STUCCO LATHE/BRICK TIES <input type="checkbox"/></li> <li>7. FRAMING / FRAMING COVER <input type="checkbox"/></li> <li>8. BUILDING FINAL <input type="checkbox"/></li> <li>9. TREE FINAL <input type="checkbox"/></li> <li>10. ROOF Final/ DEMO FINAL <input type="checkbox"/></li> <li>11. Generator Steel <input type="checkbox"/></li> <li>12. Generator Final <input type="checkbox"/></li> </ul> | <p style="border: 1px solid red; border-radius: 50%; padding: 5px; display: inline-block;">POSTED</p> | <p>(713) 650-3008 (F)</p> <p>Afternoon Inspection.</p> | <ul style="list-style-type: none"> <li>1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/></li> <li>2. POOL STEEL <input checked="" type="checkbox"/></li> <li>3. POOL DECK/PATIO STEEL <input type="checkbox"/></li> <li>4. POOL BARRIER <input type="checkbox"/></li> <li>4. POOL FINAL <input type="checkbox"/></li> <li>1. FENCE POST HOLE <input type="checkbox"/></li> <li>2. FENCE FINAL <input type="checkbox"/></li> <li>1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/></li> <li>2. DRIVEWAY FINAL <input type="checkbox"/></li> <li>3. OTHER <input type="checkbox"/></li> <li>4. TRENCH <input type="checkbox"/></li> <li>5. TEMP FENCING <input type="checkbox"/></li> </ul> |
|--|---|--|--|

CONTRACTOR/CALLER NAME: Mike Taylor  
 CONTACT TEL/PGR/MOBILE: Star Pools (713) 650-3008  
 INSPECTOR COMMENTS: Beam steel

<b>PASS</b>	<b>FAIL</b>
DATE: <u>2-13-13</u>	
TIME: <u>9:00</u>	
INSPECTOR: <u>JMP</u>	

\* VERBAL APPROVAL BY ENGINEER  
2-13-13  
9:00AM OK

# REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-13-13 TIME 2:15: AM/PM

JOB ADDRESS: 206 Millbrook

PERMIT NUMBER: 12195

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2011 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

PASS	<b>FAIL</b>
DATE:	<u>2-13-13</u>
TIME:	<u>2:15</u>
INSPECTOR:	<u>JB</u>

CONTRACTOR/CALLER NAME: House of Power

CONTACT TEL/PGR/MOBILE: ALBERT 713-349-8090

INSPECTOR COMMENTS: Need to have A Ground Rod Driven

Reinspection fee required



