

REQUEST FOR **PLUMBING / MECHANICAL** INSPECTION

DATE: 05.07.2013 TIME: _____ : _____ AM / PM

JOB ADDRESS: 458 Jankelly Ln

PERMIT NUMBER: P# 12442

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass Fail Trash Anywhere on Property
- Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass Fail Dumpster full to the Lip & Needs to be Serviced
- Pass Fail Port-O-Can Door Facing Away From Street
- Pass Fail Port-O-Can Screened and/or Needs Maintenance
- Pass Fail Tree Protective Fencing Down
- Pass Fail Filter Fabric Fencing Down
- Pass Fail High Grass and/or Tall Weeds
- Pass Fail Overall Condition of Construction Site Good _____ Poor
- _____ Verbal Warning _____ Site Cleaned at Insp. _____ City Citation Issued _____ City Notified

wednesday

INSPECTOR : George Sanders

INSPECTION DATE: 05.08.13

PLUMBING	MECHANICAL
----------	------------

- 1. Water line
- 2. Rough In
- 3. Top Out
- 4. Shower Pan
- 5. Sewer Line
- 6. WC Flange
- 7. GTO
- 8. Plumbing Final
- 9. Pool Drainage
- 10. Site Drainage
- 11. Irrigation Final
- 12. Other

(713) 812-0707 (f)



- 1. Vent Hood
- 2. Rough/cover
- 3. Mech Final
- 4. Water Heater Final
- 5. Fire Sprinkler cover (need MVFD approval)
- 6. Fire Sprinkler Final

PASS <input checked="" type="checkbox"/>	FAIL <input type="checkbox"/>
DATE: <u>5/8/13</u>	
TIME: <u>1:00</u>	
INSPECTOR: <u>[Signature]</u>	

CONTRACTOR/CALLER NAME: Lisa Fulamiti (713) 812-7070

CONTACT TEL/PGR/MOBILE: Abacus Plumbing Co.

INSPECTOR COMMENTS: plumbing final - water heater.

MIN 8" CLEARANCE @ TOP OF W/H

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 05.07.2013 TIME _____ : _____ AM / PM
 PROPERTY ADDRESS: 203 Heritage Oaks Ln
 INSPECTOR NAME: (George Sanders) # 12420

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass Fail Trash Anywhere on Property
- Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass Fail Dumpster full to the Lip & Needs to be Serviced
- Pass Fail Port-O-Can Door Facing Away From Street
- Pass Fail Port-O-Can Screened and/or Needs Maintenance
- Pass Fail Tree Protective Fencing Down
- Pass Fail Filter Fabric Fencing Down
- Pass Fail High Grass and/or Tall Weeds
- Pass Fail Overall Condition of Construction Site Good _____ Poor
- _____ Verbal Warning _____ Site Cleaned at Insp. _____ City Citation Issued _____ City Notified

DATE: 05.08.2013 *wednesday* TIME _____ : _____ AM / PM

INSPECTION TYPE

- | | | |
|---|--|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <p><i>(713) 981-9189</i></p> <p><i>Call prior to coming.</i></p> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP [] 2. POOL STEEL [] 3. POOL DECK/PATIO STEEL [] 4. POOL BARRIER [] 4. POOL FINAL [] 1. FENCE POST HOLE [] 2. FENCE FINAL [] 1. DRIVEWAY/FLATWORK FORMS [] 2. DRIVEWAY FINAL [] 3. OTHER [] 4. TRENCH [] 5. TEMP FENCING [] |
|---|--|---|

CONTRACTOR/CALLER NAME: Mark Taylor
 CONTACT TEL/PGR/MOBILE: Taylor Made Remodeling
 INSPECTOR COMMENTS: # (281) 235-5032 -

PASS	FAIL <input checked="" type="checkbox"/>
DATE: <u>5/8/13</u>	
TIME: <u>1:22</u>	
INSPECTOR: <u>95</u>	

frame -

1.) COMPLETE ELEC + A/C

2.) SEAL ALL PENETRATIONS

3.) PROVIDE FRAME PLAN TO MATCH & VERIFY BY ENGINEER

REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 05.07.2013 TIME: _____ : _____ AM / PM
 JOB ADDRESS: 358 Piney Point Rd
 PERMIT NUMBER: # 12415

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site _____ Good _____ Poor
- ___ Verbal Warning ___ Site Cleaned at Insp. ___ City Citation Issued ___ City Notified

wednes

INSPECTOR : George Sanders

INSPECTION DATE: 05.08.2013

PLUMBING	MECHANICAL
----------	------------

- 1. Water line
- 2. Rough In
- 3. Top Out
- 4. Shower Pan
- 5. Sewer Line
- 6. WC Flange
- 7. GTO
- 8. Plumbing Final
- 9. Pool Drainage
- 10. Site Drainage
- 11. Irrigation Final
- 12. Other

resident
(713) 320-7773



- 1. Vent Hood
- 2. Rough/cover
- 3. Mech Final
- 4. Water Heater Final
- 5. Fire Sprinkler cover (need MVFD approval)
- 6. Fire Sprinkler Final

PASS	FAIL <input checked="" type="checkbox"/>
DATE: <u>5/8/13</u>	
TIME: <u>1:15</u>	
INSPECTOR: <u>G. Sanders</u>	

CONTRACTOR/CALLER NAME: Leah Murphy @ (713) 722-5000

CONTACT TEL/PGR/MOBILE: Church Services

INSPECTOR COMMENTS: Mech Final

1.) Verify Max breaker size Max 35amp
ID @ Panel

REQUEST FOR ELECTRICAL INSPECTION

DATE: 5-8-13 TIME 12:00 AM / PM

JOB ADDRESS: 11518 Summerhill

PERMIT NUMBER: 12441

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments



PASS	<u>FAIL</u>
DATE:	<u>5-8-13</u>
TIME:	<u>12:00</u>
INSPECTOR:	<u>AB</u>

CONTRACTOR/CALLER NAME: Texas Electrical

CONTACT TEL/PGR/MOBILE: Elizabeth 281-795-0964

INSPECTOR COMMENTS:

J-Box not accessible
Romex needs to be stapled - not taped
Romex needs to be protected when going
thru new brick area
Too many wires hanging loose
Need Access upstairs
Need Access to inside House for
Existing Remodeled Rooms

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 05.7.2013 TIME _____ : _____ AM / PM
 PROPERTY ADDRESS: 11203 Tyne wood
 INSPECTOR NAME: (George Sanders) P# 12268

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass Fail Trash Anywhere on Property
- Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass Fail Dumpster full to the Lip & Needs to be Serviced
- Pass Fail Port-O-Can Door Facing Away From Street
- Pass Fail Port-O-Can Screened and/or Needs Maintenance
- Pass Fail Tree Protective Fencing Down
- Pass Fail Filter Fabric Fencing Down
- Pass Fail High Grass and/or Tall Weeds
- Pass Fail Overall Condition of Construction Site Good Poor
Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 05.08.2013 wednesday TIME _____ : _____ AM / PM

INSPECTION TYPE

- | | |
|--|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input checked="" type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP [2. POOL STEEL [3. POOL DECK/PATIO STEEL [4. POOL BARRIER [4. POOL FINAL [1. FENCE POST HOLE [2. FENCE FINAL [1. DRIVEWAY/FLATWORK FORMS [2. DRIVEWAY FINAL [3. OTHER [4. TRENCH [5. TEMP FENCING [|
|--|---|

POSTED

after 2:00pm.

CONTRACTOR/CALLER NAME: Catherine Williams
 CONTACT TEL/PGR/MOBILE: Boylan Co, (832) 271-4218

INSPECTOR COMMENTS: frame
Contingent on

PASS <input checked="" type="checkbox"/>	FAIL <input type="checkbox"/>
DATE: <u>5/9/13</u>	
TIME: <u>12:15</u>	
INSPECTOR: <u>MS</u>	

1.) PROVIDE ENGINEERS LETTER FOR COMPLIANCE
 INCLUDE BRICK SUPPORT ALL AREAS OVER ROOF DECKING - COMPLY 703.7 2011 IRC

2.) FLYE BLOCK / FILL GAPS AS MARKED

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 05.07.2013 TIME _____ : _____ AM / PM

PROPERTY ADDRESS: 11203 Tynewood Lane

INSPECTOR NAME: (George Sanders) P# 12248

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 05.08.2013 TIME _____ : _____ AM / PM
wednesday

INSPECTION TYPE

- | | | | |
|----------------------------|-------------------------------------|-------------------------------|--------------------------|
| 1. PRE CONSTRUCTION SITE | <input type="checkbox"/> | 1. POOL STAKE OUT/POOL SET-UP | <input type="checkbox"/> |
| 2. PIERS | <input type="checkbox"/> | 2. POOL STEEL | <input type="checkbox"/> |
| 3. FOUNDATION STEEL | <input type="checkbox"/> | 3. POOL DECK/PATIO STEEL | <input type="checkbox"/> |
| 4. RIDGE HEIGHT | <input type="checkbox"/> | 4. POOL BARRIER | <input type="checkbox"/> |
| 5. HURRICANE TIES | <input type="checkbox"/> | 4. POOL FINAL | <input type="checkbox"/> |
| 6. STUCCO LÁTHE/BRICK TIES | <input checked="" type="checkbox"/> | 1. FENCE POST HOLE | <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER | <input type="checkbox"/> | 2. FENCE FINAL | <input type="checkbox"/> |
| 8. BUILDING FINAL | <input type="checkbox"/> | 1. DRIVEWAY/FLATWORK FORMS | <input type="checkbox"/> |
| 9. TREE FINAL | <input type="checkbox"/> | 2. DRIVEWAY FINAL | <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL | <input type="checkbox"/> | 3. OTHER | <input type="checkbox"/> |
| 11. Generator Steel | <input type="checkbox"/> | 4. TRENCH | <input type="checkbox"/> |
| 12. Generator Final | <input type="checkbox"/> | 5. TEMP FENCING | <input type="checkbox"/> |
- After 2:00 P.M.*

CONTRACTOR/CALLER NAME: Anthony Williams

CONTACT TEL/PGR/MOBILE: Boylan Construction

INSPECTOR COMMENTS: Brick wall ties

PASS <input checked="" type="checkbox"/>	FAIL <input type="checkbox"/>
DATE: <u>5/8/13</u>	
TIME: <u>12:15</u>	
INSPECTOR: <u>[Signature]</u>	

1) FLASH ARCHED WINDOWS (4) @ FRONT