

REQUEST FOR ELECTRICAL INSPECTION

DATE: 5-9-13 TIME 11:20 AM / PM

JOB ADDRESS: 11314 Coloma

PERMIT NUMBER: 12445

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- | | | | |
|------------------------------|-------------------------------------|-------------------------------|--------------------------|
| 1. Temp Sump Pump Connection | <input type="checkbox"/> | 1. Electrical Pool Cover | <input type="checkbox"/> |
| 2. T-pole | <input type="checkbox"/> | 2. Electrical Pool Final | <input type="checkbox"/> |
| 3. Ditch Cover | <input type="checkbox"/> | 1. Generator Ditch Cover | <input type="checkbox"/> |
| 4. Slab Cover | <input type="checkbox"/> | 2. Generator Electrical Final | <input type="checkbox"/> |
| 5. Wall / Ceiling Cover | <input type="checkbox"/> | 1. Partial / See Comments | <input type="checkbox"/> |
| 6. TCI | <input type="checkbox"/> | | |
| 7. Meter Loop And Service | <input type="checkbox"/> | | |
| 8. Reconnect | <input type="checkbox"/> | | |
| 9. Electrical Final | <input checked="" type="checkbox"/> | | |
| 10. Landscape Lighting Cover | <input type="checkbox"/> | | |
| 11. Landscape Lighting Final | <input type="checkbox"/> | | |

PASS	FAIL
DATE:	<u>5-9-13</u>
TIME:	<u>11:20</u>
INSPECTOR:	<u>[Signature]</u>

CONTRACTOR/CALLER NAME: APS

CONTACT TEL/PGR/MOBILE: Melvin 713-856-1152

INSPECTOR COMMENTS:

Must use flex on MC Cable
from Disc. to water heads
OK any other approved method
to protect wire



Reinspection fee required