

REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 05.15.2013 TIME: _____ : _____ AM / PM

JOB ADDRESS: 11117 Beinhorn Rd.

PERMIT NUMBER: 1 p# 12401

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass Fail Trash Anywhere on Property
- Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass Fail Dumpster full to the Lip & Needs to be Serviced
- Pass Fail Port-O-Can Door Facing Away From Street
- Pass Fail Port-O-Can Screened and/or Needs Maintenance
- Pass Fail Tree Protective Fencing Down
- Pass Fail Filter Fabric Fencing Down
- Pass Fail High Grass and/or Tall Weeds
- Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

INSPECTOR: Joe Moore w/ HDR

Thursday

INSPECTION DATE: 05.16.2013

PLUMBING	MECHANICAL
1. Water line <input type="checkbox"/>	1. Vent Hood <input type="checkbox"/>
2. Rough In <input type="checkbox"/>	2. Rough/cover <input type="checkbox"/>
3. Top Out <input type="checkbox"/>	3. Mech Final <input type="checkbox"/>
4. Shower Pan <input type="checkbox"/>	4. Water Heater Final <input type="checkbox"/>
5. Sewer Line <input type="checkbox"/>	5. Fire Sprinkler cover <input type="checkbox"/> <small>(need MVFD approval)</small>
6. WC Flange <input type="checkbox"/>	6. Fire Sprinkler Final <input type="checkbox"/>
7. GTO <input type="checkbox"/>	
8. Plumbing Final <input type="checkbox"/>	
9. Pool Drainage <input type="checkbox"/>	
10. Site Drainage <input type="checkbox"/>	
11. Irrigation Final <input type="checkbox"/>	
12. Other <input type="checkbox"/>	

(832) 614-1158 (H)

Please call prior to inspection

PASS	FAIL
DATE: <u>5-16-2013</u>	
TIME: <u>10:15</u>	
INSPECTOR: <u>Joe Moore</u>	

CONTRACTOR/CALLER NAME: Kevin Mei (832) 230-0055

CONTACT TEL/PGR/MOBILE: Black Maintain Co,

INSPECTOR COMMENTS: Culvert Piping Install on the Grecian Way Side.

Culvert pipe will have to allow for some flow

Have engineer of record look at culvert and provide



REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 05.15.2013 TIME _____ : _____ AM / PM
 PROPERTY ADDRESS: George 218 Blalock Rd
 INSPECTOR NAME: (George) (Mike Kelsoquin) PH 12293

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass Fail Trash Anywhere on Property
- Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass Fail Dumpster full to the Lip & Needs to be Serviced
- Pass Fail Port-O-Can Door Facing Away From Street
- Pass Fail Port-O-Can Screened and/or Needs Maintenance
- Pass Fail Tree Protective Fencing Down
- Pass Fail Filter Fabric Fencing Down
- Pass Fail High Grass and/or Tall Weeds
- Pass Fail Overall Condition of Construction Site Good Poor
Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 05.15.2013 Thursday TIME _____ : _____ AM / PM

INSPECTION TYPE

- | | | |
|---|-------------------------------|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <p>(713) 520-5233
(F)</p> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|---|-------------------------------|---|

CONTRACTOR/CALLER NAME: Chris May
 CONTACT TEL/PGR/MOBILE: King Residential
 INSPECTOR COMMENTS: (281) 851-5789-
wind storm

PASS <input checked="" type="checkbox"/>	FAIL <input type="checkbox"/>
DATE: <u>5/16/13</u>	
TIME: <u>11:45</u>	
INSPECTOR: <u>[Signature]</u>	



REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 05.15.2013 TIME _____ : _____ AM / PM

JOB ADDRESS: 11135 N. Country Sq

PERMIT NUMBER: PH 11369

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

INSPECTOR : George Sanders

Thursday

INSPECTION DATE: 05.16.2013

PLUMBING

MECHANICAL

- 1. Water line
- 2. Rough In
- 3. Top Out
- 4. Shower Pan
- 5. Sewer Line
- 6. WC Flange
- 7. GTO
- 8. Plumbing Final
- 9. Pool Drainage
- 10. Site Drainage
- 11. Irrigation Final
- 12. Other

- 1. Vent Hood
- 2. Rough/cover
- 3. Mech Final
- 4. Water Heater Final
- 5. Fire Sprinkler cover
(need MVFD approval)
- 6. Fire Sprinkler Final

PASS <input checked="" type="checkbox"/>	FAIL
DATE: <u>5/16/13</u>	
TIME: <u>9:20</u>	
INSPECTOR: <u>[Signature]</u>	

CONTRACTOR/CALLER NAME: Sheila Murray

CONTACT TEL/PGR/MOBILE: Chewkey Piping (713) 856-5612 x 129

INSPECTOR COMMENTS: Fire sprinkler final
(Must have MVFD / Final approval)
- Cert on site.



REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 05.15.2013 TIME: _____ : _____ AM / PM

JOB ADDRESS: 11306 Green Vale Rd

PERMIT NUMBER: PH 12466

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good _____ Poor
- _____ Verbal Warning _____ Site Cleaned at Insp. _____ City Citation Issued _____ City Notified

INSPECTOR: George Sanders

Thursday

INSPECTION DATE: 05.16.2013

PLUMBING	MECHANICAL
1. Water line <input type="checkbox"/>	1. Vent Hood <input type="checkbox"/>
2. Rough In <input type="checkbox"/>	2. Rough/cover <input type="checkbox"/>
3. Top Out <input type="checkbox"/>	3. Mech Final <input type="checkbox"/>
4. Shower Pan <input type="checkbox"/>	4. Water Heater Final <input type="checkbox"/>
5. Sewer Line <input type="checkbox"/>	5. Fire Sprinkler cover <input type="checkbox"/> <small>(need MVFD approval)</small>
6. WC Flange <input type="checkbox"/>	6. Fire Sprinkler Final <input type="checkbox"/>
7. GTO <input type="checkbox"/>	
8. <u>Plumbing Final</u> <input checked="" type="checkbox"/>	
9. Pool Drainage <input type="checkbox"/>	
10. Site Drainage <input type="checkbox"/>	
11. Irrigation Final <input type="checkbox"/>	
12. Other <input type="checkbox"/>	

PASS <input checked="" type="checkbox"/>	FAIL <input type="checkbox"/>
DATE: <u>5/16/13</u>	
TIME: <u>10:10</u>	
INSPECTOR: <u>R.S.L.</u>	

CONTRACTOR/CALLER NAME: Rosa Silva

CONTACT TEL/PGR/MOBILE: Kalin Plumbing

INSPECTOR COMMENTS: (281) 608-9125

(gas) + plumbing final - on POOL UNDER GROUND
+ BALK WASH P-TRAP

OK

REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 05.15.2013 TIME: _____ : _____ AM / PM

JOB ADDRESS: 221 Millbrook St

PERMIT NUMBER: PH 11824

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

Thursday

INSPECTOR: George Sanders

INSPECTION DATE: 05.16.2013

PLUMBING	MECHANICAL
----------	------------

- 1. Water line
- 2. Rough In
- 3. Top Out
- 4. Shower Pan
- 5. Sewer Line
- 6. WC Flange
- 7. GTO
- 8. Plumbing Final
- 9. Pool Drainage
- 10. Site Drainage
- 11. Irrigation Final
- 12. Other

- 1. Vent Hood
- 2. Rough/cover
- 3. Mech Final
- 4. Water Heater Final
- 5. Fire Sprinkler cover (need MVFD approval)
- 6. Fire Sprinkler Final

PASS	FAIL <input checked="" type="checkbox"/>
DATE: <u>5/16/13</u>	
TIME: <u>10:45</u>	
INSPECTOR: <u>G. Sanders</u>	



CONTRACTOR/CALLER NAME: Thomas Laskowski (713) 464-5505

CONTACT TEL/PGR/MOBILE: A&T Plumbing Co.

INSPECTOR COMMENTS: Plumbing rough in

1.) Nail Plates @ MASTER AREA - MARKED OTHER
2.) Attic WYK WAYS DO NOT COMPLY TO WATER HEATERS

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 05.15.2013 TIME _____ : _____ AM / PM

PROPERTY ADDRESS: 650 Piny Point Rd

INSPECTOR NAME: (~~ALICE POLYMER~~) ^{Cathy Moran} tree protection fencing

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good _____ Poor
- _____ Verbal Warning _____ Site Cleaned at Insp. _____ City Citation Issued _____ City Notified

DATE: 05.16.2013 ^{Thursday} TIME _____ : _____ AM / PM

INSPECTION TYPE

- | | |
|---|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|---|---|

CONTRACTOR/CALLER NAME: Chandler Robinson

CONTACT TEL/PGR/MOBILE: Renaissance Residential

INSPECTOR COMMENTS: (713) 902-6037-

tree protection fencing

PASS <input checked="" type="checkbox"/>	FAIL <input type="checkbox"/>
DATE: <u>5-16-13</u>	
TIME: <u>1:30 PM</u>	
INSPECTOR: <u>CMORAN</u>	

Fences + signs in place

REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 05.15.2013 TIME: _____ : _____ AM / PM

JOB ADDRESS: 14 stillforest

PERMIT NUMBER: p# 12409

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

INSPECTOR : Joe Moore / HDR Thursday
~~George Sanders~~ INSPECTION DATE: 05.16.2013

PLUMBING	MECHANICAL
1. Water line <input type="checkbox"/>	1. Vent Hood <input type="checkbox"/>
2. Rough In <input type="checkbox"/>	2. Rough/cover <input type="checkbox"/>
3. Top Out <input type="checkbox"/>	3. Mech Final <input type="checkbox"/>
4. Shower Pan <input type="checkbox"/>	4. Water Heater Final <input type="checkbox"/>
5. Sewer Line <input type="checkbox"/>	5. Fire Sprinkler cover <input type="checkbox"/> <small>(need MVFD approval)</small>
6. WC Flange <input type="checkbox"/>	6. Fire Sprinkler Final <input type="checkbox"/>
7. GTO <input type="checkbox"/>	
8. Plumbing Final <input type="checkbox"/>	
9. Pool Drainage <input type="checkbox"/>	
10. Site Drainage <input type="checkbox"/>	
11. Irrigation Final <input type="checkbox"/>	
12. Other <input checked="" type="checkbox"/>	

Culvert inspection

PASS	FAIL
DATE: <u>5/16/13</u>	
TIME: <u>10:25</u>	
INSPECTOR: <u>Joe Moore</u>	

CONTRACTOR/CALLER NAME: Patterned Concrete Co;

CONTACT TEL/PGR/MOBILE: (832) 585-6607- POSTER

INSPECTOR COMMENTS: Culvert inspection

Culvert appeared to be set low. Spoke with Rick Davis on the phone. Said that culvert elevations were shot in and correct.

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 05.15.2013 TIME _____ : _____ AM / PM

PROPERTY ADDRESS: 35 East Stillforest

INSPECTOR NAME: George Sanders P# 11133

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
 - Pass Fail Dirt, Mud, Construction Tracks in Front of Property
 - Pass Fail Trash Anywhere on Property
 - Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
 - Pass Fail Dumpster full to the Lip & Needs to be Serviced
 - Pass Fail Port-O-Can Door Facing Away From Street
 - Pass Fail Port-O-Can Screened and/or Needs Maintenance
 - Pass Fail Tree Protective Fencing Down
 - Pass Fail Filter Fabric Fencing Down
 - Pass Fail High Grass and/or Tall Weeds
 - Pass Fail Overall Condition of Construction Site Good Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 05.16.2013 TIME _____ : _____ AM / PM

INSPECTION TYPE

- | | |
|---|---|
| <ul style="list-style-type: none"> 1. PRE CONSTRUCTION SITE <input type="checkbox"/> 2. PIERS <input type="checkbox"/> 3. FOUNDATION STEEL <input type="checkbox"/> 4. RIDGE HEIGHT <input type="checkbox"/> 5. HURRICANE TIES <input type="checkbox"/> 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> 7. FRAMING / FRAMING COVER <input type="checkbox"/> 8. BUILDING FINAL <input type="checkbox"/> 9. TREE FINAL <input type="checkbox"/> 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> 11. Generator Steel <input type="checkbox"/> 12. Generator Final <input type="checkbox"/> | <ul style="list-style-type: none"> 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> 2. POOL STEEL <input type="checkbox"/> 3. POOL DECK/PATIO STEEL <input type="checkbox"/> 4. POOL BARRIER <input type="checkbox"/> 4. POOL FINAL <input type="checkbox"/> 1. FENCE POST HOLE <input type="checkbox"/> 2. FENCE FINAL <input type="checkbox"/> 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> 2. DRIVEWAY FINAL <input type="checkbox"/> 3. OTHER <input type="checkbox"/> 4. TRENCH <input type="checkbox"/> 5. TEMP FENCING <input type="checkbox"/> |
|---|---|

CONTRACTOR/CALLER NAME: Andrew Engleman

CONTACT TEL/PGR/MOBILE: Gulf Coast Pavers

INSPECTOR COMMENTS: @(281) 450-3339-
drilled footing-
for front wall.

* providing engineer letter

PASS <input checked="" type="checkbox"/>	FAIL <input type="checkbox"/>
DATE: <u>5/16/13</u>	
TIME: <u>11:30</u>	
INSPECTOR: <u>A. J. Smith</u>	

OK

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 05.15.2013 TIME _____ : _____ AM / PM

PROPERTY ADDRESS: 338 Tynebridge Ln

INSPECTOR NAME: George Sanders PA-121511

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass Fail Trash Anywhere on Property
- Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass Fail Dumpster full to the Lip & Needs to be Serviced
- Pass Fail Port-O-Can Door Facing Away From Street
- Pass Fail Port-O-Can Screened and/or Needs Maintenance
- Pass Fail Tree Protective Fencing Down
- Pass Fail Filter Fabric Fencing Down
- Pass Fail High Grass and/or Tall Weeds
- Pass Fail Overall Condition of Construction Site Good _____ Poor
- _____ Verbal Warning _____ Site Cleaned at Insp. _____ City Citation Issued _____ City Notified

DATE: 05.16.2013 Thursday TIME _____ : _____ AM / PM

INSPECTION TYPE

- | | | | |
|----------------------------|-------------------------------------|-------------------------------|--------------------------|
| 1. PRE CONSTRUCTION SITE | <input type="checkbox"/> | 1. POOL STAKE OUT/POOL SET-UP | <input type="checkbox"/> |
| 2. PIERS | <input type="checkbox"/> | 2. POOL STEEL | <input type="checkbox"/> |
| 3. FOUNDATION STEEL | <input type="checkbox"/> | 3. POOL DECK/PATIO STEEL | <input type="checkbox"/> |
| 4. RIDGE HEIGHT | <input type="checkbox"/> | 4. POOL BARRIER | <input type="checkbox"/> |
| 5. HURRICANE TIES | <input checked="" type="checkbox"/> | 4. POOL FINAL | <input type="checkbox"/> |
| 6. STUCCO LATHE/BRICK TIES | <input type="checkbox"/> | 1. FENCE POST HOLE | <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER | <input type="checkbox"/> | 2. FENCE FINAL | <input type="checkbox"/> |
| 8. BUILDING FINAL | <input type="checkbox"/> | 1. DRIVEWAY/FLATWORK FORMS | <input type="checkbox"/> |
| 9. TREE FINAL | <input type="checkbox"/> | 2. DRIVEWAY FINAL | <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL | <input type="checkbox"/> | 3. OTHER | <input type="checkbox"/> |
| 11. Generator Steel | <input type="checkbox"/> | 4. TRENCH | <input type="checkbox"/> |
| 12. Generator Final | <input type="checkbox"/> | 5. TEMP FENCING | <input type="checkbox"/> |

CONTRACTOR/CALLER NAME: 338 Ltd

CONTACT TEL/PGR/MOBILE: Mark Harvie (281) 850-7120

INSPECTOR COMMENTS: hurricane clips

on - center area roof -

extension plywood nail pattern

ROOF ONLY - CENTER AREA

PASS	<input checked="" type="checkbox"/>	FAIL	<input type="checkbox"/>
DATE:	<u>5/16/13</u>		
TIME:	<u>10:00</u>		
INSPECTOR:	<u>[Signature]</u>		