

# REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 06/03/2013 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM

JOB ADDRESS: 250 Blalock Road

PERMIT NUMBER: # 12506

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass  Fail Trash Anywhere on Property
- Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass  Fail Dumpster full to the Lip & Needs to be Serviced
- Pass  Fail Port-O-Can Door Facing Away From Street
- Pass  Fail Port-O-Can Screened and/or Needs Maintenance
- Pass  Fail Tree Protective Fencing Down
- Pass  Fail Filter Fabric Fencing Down
- Pass  Fail High Grass and/or Tall Weeds
- Pass  Fail Overall Condition of Construction Site Good \_\_\_\_\_ Poor
- \_\_\_\_\_ Verbal Warning \_\_\_\_\_ Site Cleaned at Insp. \_\_\_\_\_ City Citation Issued \_\_\_\_\_ City Notified

Wednesday Thursday

INSPECTOR : George Sanders

INSPECTION DATE: 06/05/2013

## PLUMBING

## MECHANICAL

- 1. Water line
- 2. Rough In
- 3. Top Out
- 4. Shower Pan (2)
- 5. Sewer Line
- 6. WC Flange
- 7. GTO
- 8. Plumbing Final
- 9. Pool Drainage
- 10. Site Drainage
- 11. Irrigation Final
- 12. Other

- 1. Vent Hood
- 2. Rough/cover
- 3. Mech Final
- 4. Water Heater Final
- 5. Fire Sprinkler cover   
(need MVFD approval)
- 6. Fire Sprinkler Final

*Call an (1) hour prior.*

John  
632-276-3586

PASS <input checked="" type="checkbox"/>	FAIL
DATE: <u>6/5/13</u>	
TIME: <u>1:40</u>	
INSPECTOR: <u>G. Sanders</u>	

CONTRACTOR/CALLER NAME: John Majercik

CONTACT TEL/PGR/MOBILE: J.M. Majercik Plumbing Co.,  
(281) 300-6807

INSPECTOR COMMENTS: (2) Shower pan

# REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 06-03-2013 TIME        :        AM / PM  
 PROPERTY ADDRESS: 11126 Meadowick Drive  
 INSPECTOR NAME: (Mike Peloguin) P# 12306

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
  - Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
  - Pass  Fail Trash Anywhere on Property
  - Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
  - Pass  Fail Dumpster full to the Lip & Needs to be Serviced
  - Pass  Fail Port-O-Can Door Facing Away From Street
  - Pass  Fail Port-O-Can Screened and/or Needs Maintenance
  - Pass  Fail Tree Protective Fencing Down
  - Pass  Fail Filter Fabric Fencing Down
  - Pass  Fail High Grass and/or Tall Weeds
  - Pass  Fail Overall Condition of Construction Site    Good    Poor
- Verbal Warning    Site Cleaned at Insp.    City Citation Issued    City Notified

DATE: 06-05-2013 <sup>Wednesday</sup> TIME        :        AM / PM

## INSPECTION TYPE

- |   |  |
|---|--|
| <ul style="list-style-type: none"> <li>1. PRE CONSTRUCTION SITE <input type="checkbox"/></li> <li>2. PIERS <input type="checkbox"/></li> <li>3. FOUNDATION STEEL <input type="checkbox"/></li> <li>4. RIDGE HEIGHT <input type="checkbox"/></li> <li>5. HURRICANE TIES <input type="checkbox"/></li> <li>6. STUCCO LATHE/BRICK TIES <input checked="" type="checkbox"/></li> <li>7. FRAMING / FRAMING COVER <input type="checkbox"/></li> <li>8. BUILDING FINAL <input checked="" type="checkbox"/></li> <li>9. TREE FINAL <input type="checkbox"/></li> <li>10. ROOF Final/ DEMO FINAL <input type="checkbox"/></li> <li>11. Generator Steel <input type="checkbox"/></li> <li>12. Generator Final <input type="checkbox"/></li> </ul> | <ul style="list-style-type: none"> <li>1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/></li> <li>2. POOL STEEL <input type="checkbox"/></li> <li>3. POOL DECK/PATIO STEEL <input type="checkbox"/></li> <li>4. POOL BARRIER <input type="checkbox"/></li> <li>4. POOL FINAL <input type="checkbox"/></li> <li>1. FENCE POST HOLE <input checked="" type="checkbox"/></li> <li>2. FENCE FINAL <input type="checkbox"/></li> <li>1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/></li> <li>2. DRIVEWAY FINAL <input type="checkbox"/></li> <li>3. OTHER <input type="checkbox"/></li> <li>4. TRENCH <input type="checkbox"/></li> <li>5. TEMP FENCING <input type="checkbox"/></li> </ul> |
|---|--|

POSTED

CONTRACTOR/CALLER NAME: Chris Thelen  
 CONTACT TEL/PGR/MOBILE: Thompson Custom Homes  
 INSPECTOR COMMENTS: (832) 250-1291 - fence post hole

PASS	FAIL
DATE: <u>6-5-13</u>	
TIME: <u>9:40</u>	
INSPECTOR: <u>MP</u>	

OK

# REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 06.04.2013 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM Way Manor

PROPERTY ADDRESS: 11509 Memorial Drive

INSPECTOR NAME: (George Sanders) P# 12387

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass  Fail Trash Anywhere on Property
- Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass  Fail Dumpster full to the Lip & Needs to be Serviced
- Pass  Fail Port-O-Can Door Facing Away From Street
- Pass  Fail Port-O-Can Screened and/or Needs Maintenance
- Pass  Fail Tree Protective Fencing Down
- Pass  Fail Filter Fabric Fencing Down
- Pass  Fail High Grass and/or Tall Weeds
- Pass  Fail Overall Condition of Construction Site Good Poor  
Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 06.05.2013 Wednesday TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM

## INSPECTION TYPE

- |                            |                                     |                               |                          |
|----------------------------|-------------------------------------|-------------------------------|--------------------------|
| 1. PRE CONSTRUCTION SITE   | <input type="checkbox"/>            | 1. POOL STAKE OUT/POOL SET-UP | <input type="checkbox"/> |
| 2. PIERS                   | <input type="checkbox"/>            | 2. POOL STEEL                 | <input type="checkbox"/> |
| 3. FOUNDATION STEEL        | <input checked="" type="checkbox"/> | 3. POOL DECK/PATIO STEEL      | <input type="checkbox"/> |
| 4. RIDGE HEIGHT            | <input type="checkbox"/>            | 4. POOL BARRIER               | <input type="checkbox"/> |
| 5. HURRICANE TIES          | <input type="checkbox"/>            | 4. POOL FINAL                 | <input type="checkbox"/> |
| 6. STUCCO LATHE/BRICK TIES | <input type="checkbox"/>            | 1. FENCE POST HOLE            | <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER | <input type="checkbox"/>            | 2. FENCE FINAL                | <input type="checkbox"/> |
| 8. BUILDING FINAL          | <input checked="" type="checkbox"/> | 1. DRIVEWAY/FLATWORK FORMS    | <input type="checkbox"/> |
| 9. TREE FINAL              | <input type="checkbox"/>            | 2. DRIVEWAY FINAL             | <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL | <input type="checkbox"/>            | 3. OTHER                      | <input type="checkbox"/> |
| 11. Generator Steel        | <input type="checkbox"/>            | 4. TRENCH                     | <input type="checkbox"/> |
| 12. Generator Final        | <input type="checkbox"/>            | 5. TEMP FENCING               | <input type="checkbox"/> |

CONTRACTOR/CALLER NAME: Michael Ackley

CONTACT TEL/PGR/MOBILE: Morgan Moore Construction

INSPECTOR COMMENTS: (713) 818-8102

Foundation Steel

PASS	<input checked="" type="checkbox"/>	FAIL	<input type="checkbox"/>
DATE:	<u>6/5/13</u>		
TIME:	<u>1:30</u>		
INSPECTOR:	<u>G. Sanders</u>		

PROVIDE ENGINEER'S REPORT

# REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 06/03/2013 TIME: \_\_\_\_\_ : \_\_\_\_\_ AM / PM

PROPERTY ADDRESS: 221 Millbrook Street

INSPECTOR NAME: #1 12443 & #1 11752  
 (2nd floor) (main permit)

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass  Fail Trash Anywhere on Property
- Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass  Fail Dumpster full to the Lip & Needs to be Serviced
- Pass  Fail Port-O-Can Door Facing Away From Street
- Pass  Fail Port-O-Can Screened and/or Needs Maintenance
- Pass  Fail Tree Protective Fencing Down
- Pass  Fail Filter Fabric Fencing Down
- Pass  Fail High Grass and/or Tall Weeds
- Pass  Fail Overall Condition of Construction Site Good  Poor
- Verbal Warning  Site Cleaned at Insp.  City Citation Issued  City Notified

DATE: 06/05/2013 Wednesday TIME: \_\_\_\_\_ : \_\_\_\_\_ AM / PM

## INSPECTION TYPE

- |  |  |   |
|--|--|---|
| <ul style="list-style-type: none"> <li>1. PRE CONSTRUCTION SITE <input type="checkbox"/></li> <li>2. PIERS <input type="checkbox"/></li> <li>3. FOUNDATION STEEL <input type="checkbox"/></li> <li>4. RIDGE HEIGHT <input type="checkbox"/></li> <li>5. HURRICANE TIES <input type="checkbox"/></li> <li>6. STUCCO LATHE/BRICK TIES <input type="checkbox"/></li> <li>7. FRAMING / FRAMING COVER <input checked="" type="checkbox"/></li> <li>8. BUILDING FINAL <input type="checkbox"/></li> <li>9. TREE FINAL <input type="checkbox"/></li> <li>10. ROOF Final/ DEMO FINAL <input type="checkbox"/></li> <li>11. Generator Steel <input type="checkbox"/></li> <li>12. Generator Final <input type="checkbox"/></li> </ul> | <p style="font-size: 2em; font-weight: bold; color: blue;">paid<br/>ve-inspect<br/>fee</p> <p style="font-size: 1.5em; font-weight: bold; color: blue;">on job/2013</p> <div style="border: 1px solid red; border-radius: 50%; width: 40px; height: 40px; text-align: center; line-height: 40px; color: red; font-weight: bold; margin: 0 auto;">POSTED</div> <p style="font-size: 1.2em; color: blue;">(713) 875-1327</p> | <ul style="list-style-type: none"> <li>1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/></li> <li>2. POOL STEEL <input type="checkbox"/></li> <li>3. POOL DECK/PATIO STEEL <input type="checkbox"/></li> <li>4. POOL BARRIER <input type="checkbox"/></li> <li>4. POOL FINAL <input type="checkbox"/></li> <li>1. FENCE POST HOLE <input type="checkbox"/></li> <li>2. FENCE FINAL <input type="checkbox"/></li> <li>1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/></li> <li>2. DRIVEWAY FINAL <input type="checkbox"/></li> <li>3. OTHER <input type="checkbox"/></li> <li>4. TRENCH <input type="checkbox"/></li> <li>5. TEMP FENCING <input type="checkbox"/></li> </ul> |
|--|--|---|

CONTRACTOR/CALLER NAME: Jim Bob Taylor

CONTACT TEL/PGR/MOBILE: D L Doyle Construction

INSPECTOR COMMENTS: frame cover TREADS

NOTE: VERIFY FINISHED STAIR RISE

<b>PASS</b>	<b>FAIL</b> <input checked="" type="checkbox"/>
DATE: <u>6/5/13</u>	
TIME: <u>1:40</u>	
INSPECTOR: <u>N. Clark</u>	

- ~~- MECHANICAL NOT PASSED INSPECTION~~
- FRAME MIN 1 1/2" CLEARANCE TO BACK OF FIP
- MIN 2" TO FIVE R/F FRONT F/PIANE (BOTH FLOORS)
- ADD ANCHORS AS MARKED A. OR N+W
- FIRE BLOCK AS MARKED FIB
- SEAL GAPS @ CENTER F/PIANE FIRE BLOCK



# REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 06.04.2013 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM

JOB ADDRESS: 11313 Surrency Oaks Ln

PERMIT NUMBER: PH 12089

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
  - Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
  - Pass  Fail Trash Anywhere on Property
  - Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
  - Pass  Fail Dumpster full to the Lip & Needs to be Serviced
  - Pass  Fail Port-O-Can Door Facing Away From Street
  - Pass  Fail Port-O-Can Screened and/or Needs Maintenance
  - Pass  Fail Tree Protective Fencing Down
  - Pass  Fail Filter Fabric Fencing Down
  - Pass  Fail High Grass and/or Tall Weeds
  - Pass  Fail Overall Condition of Construction Site Good \_\_\_\_\_ Poor
- Verbal Warning \_\_\_\_\_ Site Cleaned at Insp. \_\_\_\_\_ City Citation Issued \_\_\_\_\_ City Notified

*Wednesday*

INSPECTOR : George Sanders

INSPECTION DATE: 06.05.2013

PLUMBING	MECHANICAL
1. Water line <input type="checkbox"/>	1. Vent Hood <input type="checkbox"/>
2. Rough In <input type="checkbox"/>	2. Rough/cover <input type="checkbox"/>
3. Top Out <input type="checkbox"/>	3. Mech Final <input type="checkbox"/>
4. Shower Pan <input type="checkbox"/>	4. Water Heater Final <input type="checkbox"/>
5. Sewer Line <input type="checkbox"/>	5. Fire Sprinkler cover <input type="checkbox"/> <small>(need MVFD approval)</small>
6. WC Flange <input type="checkbox"/>	6. Fire Sprinkler Final <input checked="" type="checkbox"/>
7. GTO <input type="checkbox"/>	
8. Plumbing Final <input type="checkbox"/>	
9. Pool Drainage <input type="checkbox"/>	
10. Site Drainage <input type="checkbox"/>	
11. Irrigation Final <input type="checkbox"/>	
12. Other <input type="checkbox"/>	



<b>PASS</b> <input checked="" type="checkbox"/>	<b>FAIL</b>
DATE: <u>6/5/13</u>	
TIME: <u>2:30</u>	
INSPECTOR: <u>[Signature]</u>	

CONTRACTOR/CALLER NAME: Scott Tepler (713) 466-9848

CONTACT TEL/PGR/MOBILE: American Fire Systems

INSPECTOR COMMENTS: fire sprinkler final  
fire Marshall - will be out site @ 2:00 p.m.

# REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 06-04-2013 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM

JOB ADDRESS: 5 Windermere

PERMIT NUMBER: PH 12454

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
  - Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
  - Pass  Fail Trash Anywhere on Property
  - Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
  - Pass  Fail Dumpster full to the Lip & Needs to be Serviced
  - Pass  Fail Port-O-Can Door Facing Away From Street
  - Pass  Fail Port-O-Can Screened and/or Needs Maintenance
  - Pass  Fail Tree Protective Fencing Down
  - Pass  Fail Filter Fabric Fencing Down
  - Pass  Fail High Grass and/or Tall Weeds
  - Pass  Fail Overall Condition of Construction Site Good  Poor
- Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

*Wednesday*  
 INSPECTION DATE: 0-6-5  
 2013

INSPECTOR: George Sanders

INSPECTION DATE: 0-6-5  
2013

PLUMBING	MECHANICAL
1. Water line <input type="checkbox"/>	1. Vent Hood <input type="checkbox"/>
2. Rough In <input type="checkbox"/>	2. Rough/cover <input type="checkbox"/>
3. Top Out <input type="checkbox"/>	3. Mech Final <input checked="" type="checkbox"/>
4. Shower Pan <input type="checkbox"/>	4. Water Heater Final <input checked="" type="checkbox"/>
5. Sewer Line <input type="checkbox"/>	5. Fire Sprinkler cover <input type="checkbox"/> <small>(need MVFD approval)</small>
6. WC Flange <input type="checkbox"/>	6. Fire Sprinkler Final <input type="checkbox"/>
7. GTO <input type="checkbox"/>	
8. Plumbing Final <input type="checkbox"/>	
9. Pool Drainage <input type="checkbox"/>	
10. Site Drainage <input type="checkbox"/>	
11. Irrigation Final <input type="checkbox"/>	
12. Other <input type="checkbox"/>	



PASS <input checked="" type="checkbox"/>	FAIL <input checked="" type="checkbox"/>
DATE: <u>6/5/13</u>	
TIME: <u>1:45</u>	
INSPECTOR: <u>[Signature]</u>	

CONTRACTOR/CALLER NAME: Naim Nasseri

CONTACT TEL/PGR/MOBILE: Air Energy Company

INSPECTOR COMMENTS: (713) 777-9000

Mechanical Final

- 1.) INSTALL MAX 35 AMP BREAKER - ID BREAKER - DISCONNECT + CONDENSER + AIRHANDLER
- 2.) FLUSH PRIMARY - WATER IN PAN
- 3.) 1" @ ROOFDECK