

# REQUEST FOR ELECTRICAL INSPECTION

DATE: 6-11-13 TIME 11:00: AM / PM

JOB ADDRESS: 11202 Wilding

PERMIT NUMBER: 12120

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- |   |  |
|---|--|
| 1. Temp Sump Pump Connection <input type="checkbox"/> | 1. Electrical Pool Cover <input type="checkbox"/>      |
| 2. T-pole <input type="checkbox"/>                    | 2. Electrical Pool Final <input type="checkbox"/>      |
| 3. Ditch Cover <input type="checkbox"/>               | 1. Generator Ditch Cover <input type="checkbox"/>      |
| 4. Slab Cover <input type="checkbox"/>                | 2. Generator Electrical Final <input type="checkbox"/> |
| 5. Wall / Ceiling Cover <input type="checkbox"/>      | 1. Partial / See Comments <input type="checkbox"/>     |
| 6. TCI <input type="checkbox"/>                       |  |
| 7. Meter Loop And Service <input type="checkbox"/>    |  |
| 8. Reconnect <input type="checkbox"/>                 |  |
| 9. Electrical Final <input type="checkbox"/>          |  |
| 10. Landscape Lighting Cover <input type="checkbox"/> |  |
| 11. Landscape Lighting Final <input type="checkbox"/> |  |

POSTED

PASS	FAIL
DATE: <u>6-11-13</u>	
TIME: <u>11:00</u>	
INSPECTOR: <u>[Signature]</u>	

rough in

CONTRACTOR/CALLER NAME: Crake Bros.

CONTACT TEL/PGR/MOBILE: Kristen 713-228-3310

INSPECTOR COMMENTS:

Need Bonds Run @TCI  
Need Floor Plug Boxes installed @TCI

Reinspection fee required