

# REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 06.17.2013 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM  
 PROPERTY ADDRESS: 11117 Beinhorn Rd  
 INSPECTOR NAME: (Miller-eloquin) #12407

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
  - Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
  - Pass  Fail Trash Anywhere on Property
  - Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
  - Pass  Fail Dumpster full to the Lip & Needs to be Serviced
  - Pass  Fail Port-O-Can Door Facing Away From Street
  - Pass  Fail Port-O-Can Screened and/or Needs Maintenance
  - Pass  Fail Tree Protective Fencing Down
  - Pass  Fail Filter Fabric Fencing Down
  - Pass  Fail High Grass and/or Tall Weeds
  - Pass  Fail Overall Condition of Construction Site Good \_\_\_\_\_ Poor
- \_\_\_ Verbal Warning \_\_\_ Site Cleaned at Insp. \_\_\_ City Citation Issued \_\_\_ City Notified

DATE: 06.17.2013 <sup>Monday</sup> TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM

## INSPECTION TYPE

- |   |  |
|---|--|
| <ul style="list-style-type: none"> <li>1. PRE CONSTRUCTION SITE <input type="checkbox"/></li> <li>2. PIERS <input type="checkbox"/></li> <li>3. FOUNDATION STEEL <input type="checkbox"/></li> <li>4. RIDGE HEIGHT <input type="checkbox"/></li> <li>5. HURRICANE TIES <input type="checkbox"/></li> <li>6. STUCCO LATHE/BRICK TIES <input type="checkbox"/></li> <li>7. FRAMING / FRAMING COVER <input type="checkbox"/></li> <li>8. BUILDING FINAL <input type="checkbox"/></li> <li>9. TREE FINAL <input type="checkbox"/></li> <li>10. ROOF Final/ DEMO FINAL <input type="checkbox"/></li> <li>11. Generator Steel <input type="checkbox"/></li> <li>12. Generator Final <input type="checkbox"/></li> </ul> | <ul style="list-style-type: none"> <li>1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/></li> <li>2. POOL STEEL <input type="checkbox"/></li> <li>3. POOL DECK/PATIO STEEL <input type="checkbox"/></li> <li>4. POOL BARRIER <input type="checkbox"/></li> <li>4. POOL FINAL <input type="checkbox"/></li> <li>1. FENCE POST HOLE <input type="checkbox"/></li> <li>2. FENCE FINAL <input type="checkbox"/></li> <li>1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/></li> <li>2. DRIVEWAY FINAL <input checked="" type="checkbox"/></li> <li>3. OTHER <input type="checkbox"/></li> <li>4. TRENCH <input type="checkbox"/></li> <li>5. TEMP FENCING <input type="checkbox"/></li> </ul> |
|---|--|

CONTRACTOR/CALLER NAME: Kevin Mei

CONTACT TEL/PGR/MOBILE: Black Mountain Const

INSPECTOR COMMENTS: (832) 230-9055-

Driveway / Flatwork Final  
PARTIAL

<b>PASS</b>	<b>FAIL</b>
DATE: <u>6.17.13</u>	
TIME: <u>9:15</u>	
INSPECTOR: <u>MP</u>	

OK

# REQUEST FOR ELECTRICAL INSPECTION

DATE: 6-17-13 TIME 10:00 AM/PM

JOB ADDRESS: 529 Hedwin

PERMIT NUMBER: 12547

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 ~~or~~ NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

PASS FAIL

DATE: 6-17-13

TIME: 10:00

INSPECTOR: B

CONTRACTOR/CALLER NAME: System Electric

CONTACT TEL/PGR/MOBILE: Pat Collins 832-627-8822

INSPECTOR COMMENTS: \_\_\_\_\_



Reinspection fee required

# REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 06.17.2013 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM

PROPERTY ADDRESS: 4 Mott Ln

INSPECTOR NAME: Mike Pelugin P# 12348

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
  - Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
  - Pass  Fail Trash Anywhere on Property
  - Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
  - Pass  Fail Dumpster full to the Lip & Needs to be Serviced
  - Pass  Fail Port-O-Can Door Facing Away From Street
  - Pass  Fail Port-O-Can Screened and/or Needs Maintenance
  - Pass  Fail Tree Protective Fencing Down
  - Pass  Fail Filter Fabric Fencing Down
  - Pass  Fail High Grass and/or Tall Weeds
  - Pass  Fail Overall Condition of Construction Site ✓ Good \_\_\_\_\_ Poor
- \_\_\_\_\_ Verbal Warning \_\_\_\_\_ Site Cleaned at Insp. \_\_\_\_\_ City Citation Issued \_\_\_\_\_ City Notified

DATE: 6.17.2013 Monday TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM

## INSPECTION TYPE

- |  |  |
|--|--|
| <ul style="list-style-type: none"> <li>1. PRE CONSTRUCTION SITE <input type="checkbox"/></li> <li>2. PIERS <input type="checkbox"/></li> <li>3. FOUNDATION STEEL <input type="checkbox"/></li> <li>4. RIDGE HEIGHT <input type="checkbox"/></li> <li>5. HURRICANE TIES <input type="checkbox"/></li> <li>6. STUCCO LATHE/BRICK TIES <input type="checkbox"/></li> <li>7. FRAMING / FRAMING COVER <input type="checkbox"/></li> <li>8. BUILDING FINAL <input checked="" type="checkbox"/></li> <li>9. TREE FINAL <input type="checkbox"/></li> <li>10. ROOF Final/ DEMO FINAL <input type="checkbox"/></li> <li>11. Generator Steel <input type="checkbox"/></li> <li>12. Generator Final <input type="checkbox"/></li> </ul> | <ul style="list-style-type: none"> <li>1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/></li> <li>2. POOL STEEL <input type="checkbox"/></li> <li>3. POOL DECK/PATIO STEEL <input type="checkbox"/></li> <li>4. POOL BARRIER <input type="checkbox"/></li> <li>4. POOL FINAL <input type="checkbox"/></li> <li>1. FENCE POST HOLE <input type="checkbox"/></li> <li>2. FENCE FINAL <input checked="" type="checkbox"/></li> <li>1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/></li> <li>2. DRIVEWAY FINAL <input type="checkbox"/></li> <li>3. OTHER <input type="checkbox"/></li> <li>4. TRENCH <input type="checkbox"/></li> <li>5. TEMP FENCING <input type="checkbox"/></li> </ul> |
|--|--|

CONTRACTOR/CALLER NAME: Choice fence

CONTACT TEL/PGR/MOBILE: (281) 250-2070-

INSPECTOR COMMENTS: fence final re-inspect  
paid - re-inspect in defn.

PASS	FAIL
DATE: <u>6-17-13</u>	
TIME: <u>9:50</u>	
INSPECTOR: <u>MP</u>	

*OK*



# REQUEST FOR ELECTRICAL INSPECTION

DATE: 6-17-13 TIME 11:30 AM / PM

JOB ADDRESS: 351 Tynebrook

PERMIT NUMBER: 11986

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- |                              |                                     |                               |                          |
|------------------------------|-------------------------------------|-------------------------------|--------------------------|
| 1. Temp Sump Pump Connection | <input type="checkbox"/>            | 1. Electrical Pool Cover      | <input type="checkbox"/> |
| 2. T-pole                    | <input type="checkbox"/>            | 2. Electrical Pool Final      | <input type="checkbox"/> |
| 3. Ditch Cover               | <input type="checkbox"/>            | 1. Generator Ditch Cover      | <input type="checkbox"/> |
| 4. Slab Cover                | <input type="checkbox"/>            | 2. Generator Electrical Final | <input type="checkbox"/> |
| 5. Wall / Ceiling Cover      | <input type="checkbox"/>            | 1. Partial / See Comments     | <input type="checkbox"/> |
| 6. TCI                       | <input checked="" type="checkbox"/> |                               |                          |
| 7. Meter Loop And Service    | <input type="checkbox"/>            |                               |                          |
| 8. Reconnect                 | <input type="checkbox"/>            |                               |                          |
| 9. Electrical Final          | <input type="checkbox"/>            |                               |                          |
| 10. Landscape Lighting Cover | <input type="checkbox"/>            |                               |                          |
| 11. Landscape Lighting Final | <input type="checkbox"/>            |                               |                          |

PASS

**FAIL**

DATE: 6-17-13

TIME: 11:30

INSPECTOR: JB

CONTRACTOR/CALLER NAME: Evergreen Solar

CONTACT TEL/PGR/MOBILE: OSCAR. 832-573-9588

INSPECTOR COMMENTS:

Need All Panel lids on  
Phase wires in panels and Meter  
can are wrongly terminated  
wires should be marked properly per phase  
Need to terminate phase wires in gutter  
Cannot double lug wire on Neutral connector  
block

Reinspection fee required

