

REQUEST FOR ELECTRICAL INSPECTION

DATE: 6-18-13 TIME 3:00: AM/PM

JOB ADDRESS: 4 MOTT

PERMIT NUMBER: 12540

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- | | |
|---|--|
| 1. Temp Sump Pump Connection <input type="checkbox"/> | 1. Electrical Pool Cover <input type="checkbox"/> |
| 2. T-pole <input type="checkbox"/> | 2. Electrical Pool Final <input type="checkbox"/> |
| 3. Ditch Cover <input type="checkbox"/> | 1. Generator Ditch Cover <input type="checkbox"/> |
| 4. Slab Cover <input type="checkbox"/> | 2. Generator Electrical Final <input type="checkbox"/> |
| 5. Wall / Ceiling Cover <input type="checkbox"/> | 1. Partial / See Comments <input type="checkbox"/> |
| 6. TCI <input type="checkbox"/> | |
| 7. Meter Loop And Service <input type="checkbox"/> | |
| 8. Reconnect <input type="checkbox"/> | |
| 9. Electrical Final <input checked="" type="checkbox"/> | |
| 10. Landscape Lighting Cover <input type="checkbox"/> | |
| 11. Landscape Lighting Final <input type="checkbox"/> | |

*paid on 6/19/2013
AK*

PASS	<u>FAIL</u>
DATE:	<u>6-18-13</u>
TIME:	<u>3:00</u>
INSPECTOR:	<u>[Signature]</u>

CONTRACTOR/CALLER NAME: Paul Electric

CONTACT TEL/PGR/MOBILE: Bon Leathers

INSPECTOR COMMENTS: Need Arc Fault installed where
Added lights or plugs



Reinspection fee required

REQUEST FOR ELECTRICAL INSPECTION

DATE: 6-18-13 TIME 2:30: AM/PM

JOB ADDRESS: 11527 Shadow Way

PERMIT NUMBER: 12573

INSPECTION DATE:

Codes Used: NFPA 70, NEC 200, or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- | | |
|---|--|
| 1. Temp Sump Pump Connection <input type="checkbox"/> | 1. Electrical Pool Cover <input checked="" type="checkbox"/> |
| 2. T-pole <input type="checkbox"/> | 2. Electrical Pool Final <input type="checkbox"/> |
| 3. Ditch Cover <input type="checkbox"/> | 1. Generator Ditch Cover <input type="checkbox"/> |
| 4. Slab Cover <input type="checkbox"/> | 2. Generator Electrical Final <input type="checkbox"/> |
| 5. Wall / Ceiling Cover <input type="checkbox"/> | 1. Partial / See Comments <input type="checkbox"/> |
| 6. TCI <input type="checkbox"/> | |
| 7. Meter Loop And Service <input type="checkbox"/> | |
| 8. Reconnect <input type="checkbox"/> | |
| 9. Electrical Final <input type="checkbox"/> | |
| 10. Landscape Lighting Cover <input type="checkbox"/> | |
| 11. Landscape Lighting Final <input type="checkbox"/> | |

PASS	<u>FAIL</u>
DATE:	<u>6-18-13</u>
TIME:	<u>2:30</u>
INSPECTOR:	<u>[Signature]</u>

CONTRACTOR/CALLER NAME: Blue Gray

CONTACT TEL/PGR/MOBILE: Jessica 281-498-0602

INSPECTOR COMMENTS: NOT READY YET!!
Still Running Conduits



Reinspection fee required