

# REQUEST FOR ELECTRICAL INSPECTION

DATE: 7-2-13 TIME 3:20 AM/PM

JOB ADDRESS: 206 Millbrook

PERMIT NUMBER: 12611

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- |   |  |
|---|--|
| 1. Temp Sump Pump Connection <input type="checkbox"/>       | 1. Electrical Pool Cover <input type="checkbox"/>      |
| 2. T-pole <input type="checkbox"/>                          | 2. Electrical Pool Final <input type="checkbox"/>      |
| 3. Ditch Cover <input type="checkbox"/>                     | 1. Generator Ditch Cover <input type="checkbox"/>      |
| 4. Slab Cover <input type="checkbox"/>                      | 2. Generator Electrical Final <input type="checkbox"/> |
| 5. Wall / Ceiling Cover <input checked="" type="checkbox"/> | 1. Partial / See Comments <input type="checkbox"/>     |
| 6. TCI <input type="checkbox"/>                             |  |
| 7. Meter Loop And Service <input type="checkbox"/>          |  |
| 8. Reconnect <input type="checkbox"/>                       |  |
| 9. Electrical Final <input type="checkbox"/>                |  |
| 10. Landscape Lighting Cover <input type="checkbox"/>       |  |
| 11. Landscape Lighting Final <input type="checkbox"/>       |  |

PASS	<u>FAIL</u>
DATE:	<u>7-2-13</u>
TIME:	<u>3:20</u>
INSPECTOR:	<u>JB</u>

CONTRACTOR/CALLER NAME: Bove Electrical Services

CONTACT TEL/PGR/MOBILE: 832-738-1356

INSPECTOR COMMENTS:

Bath circuits not just feeding bathrooms  
on single bath lights.  
Cannot bundle wires  
Protect wires from gas piping  
Screw in ground screws on Metal  
Boxes  
Cannot bundle wires  
Family Rm. Add plug between doors to  
Outside  
Formal, Billiards Add plugs per code

Reinspection fee required

# REQUEST FOR ELECTRICAL INSPECTION

DATE: 7-2-13 TIME 2:40: AM / PM

JOB ADDRESS: 11214 Tyne Ct

PERMIT NUMBER: 12436

INSPECTION DATE:

Codes Used: NFPA 70, NEC 2005 or NEC 2011

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Dave Whittaker 3)

- 1. Temp Sump Pump Connection
- 2. T-pole
- 3. Ditch Cover
- 4. Slab Cover
- 5. Wall / Ceiling Cover
- 6. TCI
- 7. Meter Loop And Service
- 8. Reconnect
- 9. Electrical Final
- 10. Landscape Lighting Cover
- 11. Landscape Lighting Final

- 1. Electrical Pool Cover
- 2. Electrical Pool Final
- 1. Generator Ditch Cover
- 2. Generator Electrical Final
- 1. Partial / See Comments

<u>PASS</u>	FAIL
DATE: <u>7-2-13</u>	
TIME: <u>240</u>	
INSPECTOR: <u>JB</u>	

CONTRACTOR/CALLER NAME: Hurricane Equipment

CONTACT TEL/PGR/MOBILE: Dennis 713-702-0895

INSPECTOR COMMENTS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Reinspection fee required