

REQUEST FOR INSPECTION

CALL DATE: 9-23-21 TIME 9:50 AM / PM
 PROPERTY ADDRESS: 621 Piney Point PERMIT NUMBER: 17613

INSPECTION INFORMATION

INSPECTOR: ☐ Bob Baldwin ☒ Jason Bienek ☐ Gary Moran ☐ City Engineer _____

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Electrical T-Pole	Mechanical Final (Wine Room)
Stair Compliance	Electrical Cover	Sewer Disconnect
Framing Only	Electrical Ditch Cover	Plumbing Water Line
Frame Cover	Electrical TCI	Plumbing Sewer Line
Poly Seal	Electrical Reconnect	Plumbing Ground
Insulation	Pool Electrical Underground	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Cover	Plumbing Gas (GT0- House)
Brick Tie	Pool Electrical Final	Plumbing Cover
Stucco Lathe	Electrical Final	Plumbing Final
Building Final	Temporary Drainage	Pool Plumbing Cover
Irrigation Trench / Tree Final	Drainage Partial	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Cover	Plumbing Pool Final
Driveway Final	Drainage Final	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Fire Sprinkler Cover	Irrigation Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Final	Other/Miscellaneous

CONTRACTOR NAME: Highlander Electrical

CONTACT PHONE/EMAIL: 781 832-641-8095

INSPECTOR COMMENTS: _____

PASS ☒ FAIL ☐

DATE: 9-23-21

TIME: 9:50

INSPECTOR: Jason

*Missing Arc Fault Protection
 Need to plank off plug in Laundry Bath
 Need plug to serve Vanity in Powder Bath
 Need to GFI Dryer & Washer*

☒ Re-Inspection Fee Required

REQUEST FOR INSPECTION

CALL DATE: 9-17-21 TIME 11:53 AM PM

PROPERTY ADDRESS: 621 Piney Point PERMIT NUMBER: _____

INSPECTION INFORMATION

INSPECTOR: ☐ Bob Baldwin ☒ Jason Bienek ☐ Cary Moran ☐ City Engineer _____

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Electrical T-Pole	Mechanical Final (Wine Room)
Stair Compliance	Electrical Cover	Sewer Disconnect
Framing Only	Electrical Ditch Cover	Plumbing Water Line
Frame Cover	Electrical TCI	Plumbing Sewer Line
Poly Seal	Electrical Reconnect	Plumbing Ground
Insulation	Pool Electrical Underground	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Cover	Plumbing Gas (GT0- House)
Brick Tie	Pool Electrical Final	Plumbing Cover
Stucco Lathe	Electrical Final	Plumbing Final
Building Final	Temporary Drainage	Pool Plumbing Cover
Irrigation Trench / Tree Final	Drainage Partial	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Cover	Plumbing Pool Final
Driveway Final	Drainage Final	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Fire Sprinkler Cover	Irrigation Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Final	Other/Miscellaneous

CONTRACTOR NAME: Highlander Electric

CONTACT PHONE/EMAIL: John 832-641-8095

INSPECTOR COMMENTS: _____

PASS ☒ FAIL

DATE: 9-17-21

TIME: 11:53

INSPECTOR: Jason

Handy Plug - not GFI Protected
Kitchen Plug mold- too high must not be more than 20" above Counter - missing GFI
Kitchen island plug not GFI Protected
Handy Bath plug - not GFI Protected
2 gang plate missing Pantry
missing floor plug cover
1st incomplete

☒ Re-Inspection Fee Required