

REQUEST FOR INSPECTION

CALL DATE: 9-1-2022 TIME 11:09 AM / PM
 PROPERTY ADDRESS: 207 Kinkaid School Drive PERMIT NUMBER: # 19159

INSPECTION INFORMATION

INSPECTOR: Bob Baldwin Jason Bienek Cary Moran City Engineer Joe Moore w/ HDR Engineering

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Electrical T-Pole	Mechanical Final (Wine Room)
Stair Compliance	Electrical Cover	Sewer Disconnect
Framing Only	Electrical Ditch Cover	Plumbing Water Line
Frame Cover	Electrical TCI	Plumbing Sewer Line
Poly Seal	Electrical Reconnect	Plumbing Ground
Insulation	Pool Electrical Underground	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Cover	Plumbing Gas (GT0- House)
Brick Tie	Pool Electrical Final	Plumbing Cover
Stucco Lathe	Electrical Final	Plumbing Final
Building Final	Temporary Drainage	Pool Plumbing Cover
Irrigation Trench / Tree Final	Drainage Partial <i>TEMP DRAIN</i>	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Cover	Plumbing Pool Final
Driveway Final	Drainage Final	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Fire Sprinkler Cover	Irrigation Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Final	Other/Miscellaneous

CONTRACTOR NAME: Marco Avila (832) 428-0610
 CONTACT PHONE/EMAIL: w/ Build48-
 INSPECTOR COMMENTS: Temp Drainage partial.

PASS **FAIL**
 DATE: 9-1-22
 TIME: 11:09
 INSPECTOR: Cole K...

Appears pipe is SDR 35, approved is SDR 26 on the drainage plan.
Need reinforced filter fabric fencing around the lot.
Missing center inlet to curb shown on the drainage plan.
Review inlet TG elevations and resubmit drainage plan if revisions are committed.

Re-Inspection Fee Required