

REQUEST FOR INSPECTION

CALL DATE: 1-18-24 TIME 11:30 AM PM
 PROPERTY ADDRESS: 3 Fernham Park PERMIT NUMBER: 19309

INSPECTOR 20

Bob Baldwin Jason Bienek Cary Moran Jose Gomez City Engineer _____

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set-Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
<u>Building Final</u>	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: 800 Builders

CONTACT PHONE/EMAIL: Clayton

INSPECTOR COMMENTS: 979-224-6593

PASS FAIL

DATE: 1-18-24

TIME: 11-30

INSPECTOR: Jason

Partial
Bldg final - inside only

Re-Inspection Fee Required

Need gas to pause
Need Pool Final
Need generator final
Need Drive alarms - part of pool