

REQUEST FOR INSPECTION

CALL DATE: 11/19/23 TIME : (AM/PM)

PROPERTY ADDRESS: 11020 N Country Square PERMIT NUMBER: # 19427

INSPECTOR

Bob Baldwin
 Jason Bienek
 Cary Moran
 Jose Gomez
 City Engineer HBK-Cole

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	<u>Drainage Cover</u>	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: Jelasio S. w/ Salazar ^{Scapes}

CONTACT PHONE/EMAIL: # 832-566-5871

INSPECTOR COMMENTS: Drainage cover

PASS FAIL
 DATE: 11/19/23
 TIME: 12:15
 INSPECTOR: [Signature]

Re-Inspection Fee Required

Pipe must be SDR 26
as shown on drainage plan.
No R-Filter-Fabric-Fence.
No inlets as shown on drainage plan.
Pipe is not aligned as shown on drainage plan.
Bends in pipe not shown on drainage plan
7 downspouts require black pipe.
Missing pipe/inlets in NE corner
OK to cover downspouts.