

REQUEST FOR INSPECTION

CALL DATE: 01/19/2023 TIME: _____ : _____ AM / PM

PROPERTY ADDRESS: 25 Windermere LN PERMIT NUMBER: P#19389

INSPECTOR

Bob Baldwin
 Jason Bienek
 Cary Moran
 Jose Gomez
 City Engineer W/ADREngineering Co, wife

| | | |
|-------------------------------------|--------------------------------------|--------------------------------------|
| Demolition | Generator Concrete Steel Pad | Mechanical Cover |
| Temporary Tree Protection Fencing | Generator Final - Operative | Mechanical Vent Hood |
| Pre-Construction Site | Fence Post Hole | Mechanical Grill Seal |
| Piers | Fence Final | Mechanical Box Seal |
| Foundation Repair | Pool Stake Out & Pool Doc Box Set Up | Mechanical Air Make Up |
| Foundation Steel – Survey Verified | Deck Steel / Pool Steel | Mechanical Final |
| Hurricane Strapping – Exterior Wall | Deck Final / Pool Final | Mechanical Change Out |
| Wall Board Exterior | Roof Final | Mechanical Cover (Wine Room) |
| Ridge Height - Verification | Synthetic Turf | Mechanical Final (Wine Room) |
| Stair Compliance | Electrical T-Pole | Sewer Disconnect |
| Framing Only | Electrical Cover | Plumbing Water Line |
| Frame Cover | Electrical Ditch Cover | Plumbing Sewer Line |
| Poly Seal | Electrical TCI | Plumbing Ground |
| Insulation | Electrical Reconnect | Plumbing Shower Pan/Wall Board |
| Wall Board Interior | Pool Electrical Underground | Plumb Gas: House / Pool / Generator |
| Brick Tie | Pool Electrical Cover | Plumbing Cover |
| Stucco Lathe | Pool Electrical Final | Plumbing Final |
| Building Final | Electrical Final | Pool Plumbing Cover |
| Tree Final | <u>Temporary Drainage</u> | Pool Plumbing Vacuum Breaker, P-Trap |
| Driveway / Steel | Drainage Partial | Plumbing Pool Final |
| Driveway Final | Drainage Cover | Water Heater Final |
| Sidewalk/Flatwork/Pavers Steel | Drainage Final | Irrigation Trench / Final |
| Sidewalk/Flatwork/Paver Final | Fire Sprinkler Cover / Final | Other/Miscellaneous |

CONTRACTOR NAME: Belinda Orzoco

CONTACT PHONE/EMAIL: #281.900.8628

INSPECTOR COMMENTS: Anthony & Sylvan Pools
Temp pool drainage.

PASS
 FAIL

DATE: 1-19-23

TIME: 1:00

INSPECTOR: [Signature]

Re-Inspection Fee Required

No Reinforced Filter Fabric Fence as shown on Temp Drainage Plan.

Bends in all pipe lines not shown on Drainage Plan.

Inlets missing from specified areas, inlets not placed at Bends/Junctions as shown on Drainage Plan.

Pipe is not SDR 26.

Out falls through curb require 4x4 inch pipes as shown on Drainage Plan.