

Plumbing

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 5-27-21 TIME _____:____ AM / PM

PROPERTY ADDRESS: 10 Windermere Lane

PERMIT NUMBER: 17847

- ☐ Pass ☐ Fail Street Clean In Front of Property- (Nothing in Gutter)
☐ Pass ☐ Fail Dirt, Mud, Construction Tracks in Front of Property
☐ Pass ☐ Fail Trash Anywhere on Property
☐ Pass ☐ Fail O-Tolerance for Lunch Trash This May Result in
Project to be Temporarily Shut Down!
☐ Pass ☐ Fail Dumpster full to the Lip & Needs to be Serviced
☐ Pass ☐ Fail Port-O-Can Door Facing Away From Street
☐ Pass ☐ Fail Port-O-Can Screened and/or Needs Maintenance
☐ Pass ☐ Fail Tree Protective Fencing Down
☐ Pass ☐ Fail Filter Fabric Fencing Down
☐ Pass ☐ Fail High Grass and/or Tall Weeds
☐ Pass ☐ Fail Overall Condition of Construction Site ____ Good ____ Poor
____ Verbal Warning ____ Site Cleaned at Insp. ____ City Citation Issued ____ City Notified

DATE: 5-27-21 TIME _____ AM/PM

INSPECTOR : 1) Jason Bienek 2) Bob Baldwin

INSPECTION TYPE

1. PRE CONSTRUCTION SITE ☐
2. PIERS ☐
3. FOUNDATION STEEL ☐
4. RIDGE HEIGHT ☐
5. HURRICANE TIES ☐
6. STUCCO LATHE/BRICK TIES ☐
7. FRAMING / FRAMING COVER ☐
8. BUILDING FINAL ☐
9. TREE FINAL ☐
10. ROOF Final/ DEMO FINAL ☐
11. Generator Steel ☐
12. Generator Final ☐

Shower
Pan
reinspect

1. POOL STAKE OUT/POOL SET-UP ☐
2. POOL STEEL ☐
3. POOL DECK/PATIO STEEL ☐
4. POOL BARRIER ☐
4. POOL FINAL ☐
1. FENCE POST HOLE ☐
2. FENCE FINAL ☐
1. DRIVEWAY/FLATWORK FORMS ☐
2. DRIVEWAY FINAL ☐
3. OTHER ☐
4. TRENCH ☐
5. TEMP FENCING ☐

CONTRACTOR/CALLER NAME: Pro Plumber Julio

CONTACT TEL/PGR/MOBILE: 832-955-4272

INSPECTOR COMMENTS: _____

PASS	FAIL
DATE: <u>5-27-21</u>	
TIME: <u>9:19</u>	
INSPECTOR: <u>Bob Baldwin</u>	

☐ Reinspection fee required

Plumbing

REQUEST FOR **STRUCTURAL** INSPECTION

CALL DATE: 5-25-21 TIME : AM / PM

PROPERTY ADDRESS: 10 Windermere Lane

PERMIT NUMBER: 17847

- ☐ Pass ☐ Fail Street Clean In Front of Property- (Nothing in Gutter)
☐ Pass ☐ Fail Dirt, Mud, Construction Tracks in Front of Property
☐ Pass ☐ Fail Trash Anywhere on Property
☐ Pass ☐ Fail O-Tolerance for Lunch Trash This May Result in
Project to be Temporarily Shut Down!
☐ Pass ☐ Fail Dumpster full to the Lip & Needs to be Serviced
☐ Pass ☐ Fail Port-O-Can Door Facing Away From Street
☐ Pass ☐ Fail Port-O-Can Screened and/or Needs Maintenance
☐ Pass ☐ Fail Tree Protective Fencing Down
☐ Pass ☐ Fail Filter Fabric Fencing Down
☐ Pass ☐ Fail High Grass and/or Tall Weeds
☐ Pass ☐ Fail Overall Condition of Construction Site Good Poor
 Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 5-25-21 TIME AM/PM

INSPECTOR : 1) Jason Bienek 2) Bob Baldwin

INSPECTION TYPE

- | | | | |
|----------------------------|--------------------------|-------------------------------|--------------------------|
| 1. PRE CONSTRUCTION SITE | <input type="checkbox"/> | 1. POOL STAKE OUT/POOL SET-UP | <input type="checkbox"/> |
| 2. PIERS | <input type="checkbox"/> | 2. POOL STEEL | <input type="checkbox"/> |
| 3. FOUNDATION STEEL | <input type="checkbox"/> | 3. POOL DECK/PATIO STEEL | <input type="checkbox"/> |
| 4. RIDGE HEIGHT | <input type="checkbox"/> | 4. POOL BARRIER | <input type="checkbox"/> |
| 5. HURRICANE TIES | <input type="checkbox"/> | 4. POOL FINAL | <input type="checkbox"/> |
| 6. STUCCO LATHE/BRICK TIES | <input type="checkbox"/> | 1. FENCE POST HOLE | <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER | <input type="checkbox"/> | 2. FENCE FINAL | <input type="checkbox"/> |
| 8. BUILDING FINAL | <input type="checkbox"/> | 1. DRIVEWAY/FLATWORK FORMS | <input type="checkbox"/> |
| 9. TREE FINAL | <input type="checkbox"/> | 2. DRIVEWAY FINAL | <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL | <input type="checkbox"/> | 3. OTHER | <input type="checkbox"/> |
| 11. Generator Steel | <input type="checkbox"/> | 4. TRENCH | <input type="checkbox"/> |
| 12. Generator Final | <input type="checkbox"/> | 5. TEMP FENCING | <input type="checkbox"/> |

CONTRACTOR/CALLER NAME: Pro Plumber

CONTACT TEL/PGR/MOBILE: 832 955 4272

INSPECTOR COMMENTS:

PASS	FAIL
DATE:	<u>5-25-21</u>
TIME:	<u>9:40</u>
INSPECTOR:	<u>BbB 3332</u>

Upstairs Shower Pan
has no water outlet

☒ Reinspection fee required

REQUEST FOR INSPECTION

CALL DATE: 5-10-21 TIME _____:_____ AM / PM

PROPERTY ADDRESS: 10 Windermere Lane

PERMIT NUMBER: 17748

INSPECTION INFORMATION

DATE PERFORMED: 5-10-21 TIME _____:_____ AM / PM

INSPECTOR: 1) Bob Baldwin _____ 4) Jason Bienek _____
 2) Cary Moran _____ 5) Other _____
 3) City Engineer _____

Demolition (Main House)	Sidewalk/Flatwork/Pavers Steel	Electrical Ditch Cover
Demolition (Pool Only)	Sidewalk/Flatwork/Paver Final	Electrical TCI
Temporary Tree Protection Fencing	Generator Concrete Steel Pad	Electrical Final
Pre-Construction Site	Generator Final - Operative	Mechanical Vent Hood
Piers	Partial Trench Inspection	Mechanical Grill Seal
Foundation Repair	Trench Inspection	Mechanical Box Seal
Foundation Steel – Survey Verified	Irrigation Final	Mechanical Air Make Up
Hurricane Strapping – Exterior Wall	Fence Partial Post Hole	Mechanical Final
Wall Board Exterior	Fence Post Hole	Mechanical Cover (Wine Room)
Ridge Height	Fence Final	Mechanical Final (Wine Room)
Stair Compliance	Temporary Drainage	Fire Sprinkler Cover
Framing Only	Drainage Partial	Fire Sprinkler Final
Frame Cover	Drainage Cover	Pool Stake Out & Pool Doc Box Set Up
Poly Seal	Drainage Culvert	Deck Steel
Insulation	Drainage Final	Deck Final
Wall Board Interior	Plumbing Water Line	Pool Final
Brick Tie	Plumbing Sewer Line	Pool Electrical Underground
Stucco Lathe	Plumbing Ground	Pool Electrical Cover
Building Final	Plumbing Shower Pan/Wall Board	Pool Electrical Final
Tree Final	Plumbing Gas (GT0- House)	Pool Plumbing Cover
Driveway / Partial	Plumbing Cover	Pool Plumbing Vacuum Breaker, P-Trap, Gas Final
Driveway / Steel	Plumbing Final	Plumbing Pool Final
Driveway Final	Electrical T-Pole	Water Heater Final

CONTRACTOR NAME: Pro Plumbing

CONTACT PHONE/EMAIL: 8-955-4272

INSPECTOR COMMENTS: _____

PASS **FAIL**

DATE: 5-10-21

TIME: 4:15

INSPECTOR: _____

☐ Re-Inspection Fee Required

REQUEST FOR INSPECTION

CALL DATE: 5-6-21 TIME : AM / PM

PROPERTY ADDRESS: 10 Windermere Lane

PERMIT NUMBER: 17847

INSPECTION INFORMATION

DATE PERFORMED: 5-6-21 TIME : AM / PM

INSPECTOR: 1) Bob Baldwin 4) Jason Bienek
 2) Cary Moran 5) Other
 3) City Engineer

Demolition (Main House)	Sidewalk/Flatwork/Pavers Steel	Electrical Ditch Cover
Demolition (Pool Only)	Sidewalk/Flatwork/Paver Final	Electrical TCI
Temporary Tree Protection Fencing	Generator Concrete Steel Pad	Electrical Final
Pre-Construction Site	Generator Final - Operative	Mechanical Vent Hood
Piers	Partial Trench Inspection	Mechanical Grill Seal
Foundation Repair	Trench Inspection	Mechanical Box Seal
Foundation Steel – Survey Verified	Irrigation Final	Mechanical Air Make Up
Hurricane Strapping – Exterior Wall	Fence Partial Post Hole	Mechanical Final
Wall Board Exterior	Fence Post Hole	Mechanical Cover (Wine Room)
Ridge Height	Fence Final	Mechanical Final (Wine Room)
Stair Compliance	Temporary Drainage	Fire Sprinkler Cover
Framing Only	Drainage Partial	Fire Sprinkler Final
Frame Cover	Drainage Cover	Pool Stake Out & Pool Doc Box Set Up
Poly Seal	Drainage Culvert	Deck Steel
Insulation	Drainage Final	Deck Final
Wall Board Interior	Plumbing Water Line	Pool Final
Brick Tie	Plumbing Sewer Line	Pool Electrical Underground
Stucco Lathe	<u>Plumbing Ground</u>	Pool Electrical Cover
Building Final	Plumbing Shower Pan/Wall Board	Pool Electrical Final
Tree Final	Plumbing Gas (GTO- House)	Pool Plumbing Cover
Driveway / Partial	Plumbing Cover	Pool Plumbing Vacuum Breaker, P-Trap, Gas Final
Driveway / Steel	Plumbing Final	Plumbing Pool Final
Driveway Final	Electrical T-Pole	Water Heater Final

CONTRACTOR NAME: Pro Plumber

CONTACT PHONE/EMAIL: 8-955-4272

INSPECTOR COMMENTS: Need to extend vent

pipes trough roof
upstairs

PASS

FAIL

DATE: 5-6-21

TIME: 11:20

INSPECTOR: Bob B 3330

☒ Re-Inspection Fee Required