

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 5-21-21 TIME : AM / PM

PROPERTY ADDRESS:**PERMIT NUMBER:**

- | | | |
|---|--|--|
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Street Clean In Front of Property- (Nothing in Gutter) |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Dirt, Mud, Construction Tracks in Front of Property |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Trash Anywhere on Property |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | O-Tolerance for Lunch Trash This May Result in
Project to be Temporarily Shut Down! |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Dumpster full to the Lip & Needs to be Serviced |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Port-O-Can Door Facing Away From Street |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Port-O-Can Screened and/or Needs Maintenance |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Tree Protective Fencing Down |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Filter Fabric Fencing Down |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | High Grass and/or Tall Weeds |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Overall Condition of Construction Site _____ Good _____ Poor |
| <input type="checkbox"/> Verbal Warning | <input type="checkbox"/> Site Cleaned at Insp. | <input type="checkbox"/> City Citation Issued <input type="checkbox"/> City Notified |

DATE: 5-21-21 TIME 1:00 AM/PM

INSPECTOR : 1) Jason Bienek **2) Bob Baldwin**

INSPECTION TYPE

- | | |
|----------------------------|--------------------------|
| 1. PRE CONSTRUCTION SITE | <input type="checkbox"/> |
| 2. PIERS | <input type="checkbox"/> |
| 3. FOUNDATION STEEL | <input type="checkbox"/> |
| 4. RIDGE HEIGHT | <input type="checkbox"/> |
| 5. HURRICANE TIES | <input type="checkbox"/> |
| 6. STUCCO LATHE/BRICK TIES | <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER | <input type="checkbox"/> |
| 8. BUILDING FINAL | <input type="checkbox"/> |
| 9. TREE FINAL | <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL | <input type="checkbox"/> |
| 11. Generator Steel | <input type="checkbox"/> |
| 12. Generator Final | <input type="checkbox"/> |

- | | |
|-------------------------------|--------------------------|
| 1. POOL STAKE OUT/POOL SET-UP | <input type="checkbox"/> |
| 2. POOL STEEL | <input type="checkbox"/> |
| 3. POOL DECK/PATIO STEEL | <input type="checkbox"/> |
| 4. POOL BARRIER | <input type="checkbox"/> |
| 4. POOL FINAL | <input type="checkbox"/> |
| 1. FENCE POST HOLE | <input type="checkbox"/> |
| 2. FENCE FINAL | <input type="checkbox"/> |
| 1. DRIVEWAY/FLATWORK FORMS | <input type="checkbox"/> |
| 2. DRIVEWAY FINAL | <input type="checkbox"/> |
| 3. OTHER | <input type="checkbox"/> |
| 4. TRENCH | <input type="checkbox"/> |
| 5. TEMP FENCING | <input type="checkbox"/> |

CONTRACTOR/CALLER NAME:

CONTACT TEL/PGR/MOBILE:

INSPECTOR COMMENTS:

PASS	FAIL
DATE: 5-21-21	
TIME: 10:15 2:25	
INSPECTOR: BJB	3330

☐ **Reinspection fee required**

REQUEST FOR INSPECTION

CALL DATE: 5-17-21 TIME : AM / PM
PROPERTY ADDRESS: 531 Piney Point Rd
PERMIT NUMBER: 16731

INSPECTION INFORMATION

DATE PERFORMED: 5-17-21 TIME : AM / PM
INSPECTOR: 1) Bob Baldwin 4) Jason Bienek
2) Cary Moran 5) Other
3) City Engineer

Demolition (Main House)	Sidewalk/Flatwork/Pavers Steel	Electrical Ditch Cover
Demolition (Pool Only)	Sidewalk/Flatwork/Paver Final	Electrical TCI
Temporary Tree Protection Fencing	Generator Concrete Steel Pad	Electrical Final
Pre-Construction Site	Generator Final - Operative	Mechanical Vent Hood
Piers	Partial Trench Inspection	Mechanical Grill Seal
Foundation Repair	Trench Inspection	Mechanical Box Seal
Foundation Steel – Survey Verified	Irrigation Final	Mechanical Air Make Up
Hurricane Strapping – Exterior Wall	Fence Partial Post Hole	Mechanical Final
Wall Board Exterior	Fence Post Hole	Mechanical Cover (Wine Room)
Ridge Height	Fence Final	Mechanical Final (Wine Room)
Stair Compliance	Temporary Drainage	Fire Sprinkler Cover
Framing Only	Drainage Partial	Fire Sprinkler Final
Frame Cover	Drainage Cover	Pool Stake Out & Pool Doc Box Set Up
Poly Seal	Drainage Culvert	Deck Steel
Insulation	Drainage Final	Deck Final
Wall Board Interior	Plumbing Water Line	Pool Final
Brick Tie	Plumbing Sewer Line	Pool Electrical Underground
Stucco Lathe	Plumbing Ground	Pool Electrical Cover
Building Final	Plumbing Shower Pan/Wall Board	Pool Electrical Final
Tree Final	Plumbing Gas (GTO- House)	Pool Plumbing Cover
Driveway / Partial	Plumbing Cover	Pool Plumbing Vacuum Breaker, P-Trap, Gas Final
Driveway / Steel	Plumbing Final	Plumbing Pool Final
Driveway Final	Electrical T-Pole	Water Heater Final

CONTRACTOR NAME: Triple G
CONTACT PHONE/EMAIL: 713 584 9919
INSPECTOR COMMENTS:

2 test & both
times losing pressure

PASS	FAIL
DATE: 5-17-21	
TIME: 3:45	
INSPECTOR: Bob B 3330	

☒ Re-Inspection Fee Required

REQUEST FOR INSPECTION

CALL DATE: 5-12-21 TIME _____: _____ AM / PM

PROPERTY ADDRESS: 531 Piney Point

PERMIT NUMBER: 16731

INSPECTION INFORMATION

DATE PERFORMED: 5-12-21 TIME _____: _____ AM / PM

INSPECTOR: 1) Bob Baldwin 4) Jason Bienek
 2) Cary Moran 5) Other
 3) City Engineer

Demolition (Main House)	Sidewalk/Flatwork/Pavers Steel	Electrical Ditch Cover
Demolition (Pool Only)	Sidewalk/Flatwork/Paver Final	Electrical TCI
Temporary Tree Protection Fencing	Generator Concrete Steel Pad	Electrical Final
Pre-Construction Site	Generator Final - Operative	Mechanical Vent Hood
Piers	Partial Trench Inspection	Mechanical Grill Seal
Foundation Repair	Trench Inspection	Mechanical Box Seal
Foundation Steel – Survey Verified	Irrigation Final	Mechanical Air Make Up
Hurricane Strapping – Exterior Wall	Fence Partial Post Hole	Mechanical Final
Wall Board Exterior	Fence Post Hole	Mechanical Cover (Wine Room)
Ridge Height	Fence Final	Mechanical Final (Wine Room)
Stair Compliance	Temporary Drainage	Fire Sprinkler Cover
Framing Only	Drainage Partial	Fire Sprinkler Final
Frame Cover	Drainage Cover	Pool Stake Out & Pool Doc Box Set Up
Poly Seal	Drainage Culvert	Deck Steel
Insulation	Drainage Final	Deck Final
Wall Board Interior	Plumbing Water Line	Pool Final
Brick Tie	Plumbing Sewer Line	Pool Electrical Underground
Stucco Lathe	Plumbing Ground	Pool Electrical Cover
Building Final	Plumbing Shower Pan/Wall Board	Pool Electrical Final
Tree Final	<u>Plumbing Gas (GTO- House)</u>	Pool Plumbing Cover
Driveway / Partial	Plumbing Cover	Pool Plumbing Vacuum Breaker, P-Trap, Gas Final
Driveway / Steel	Plumbing Final	Plumbing Pool Final
Driveway Final	Electrical T-Pole	Water Heater Final

CONTRACTOR NAME: Triple G Plumbing

CONTACT PHONE/EMAIL: 7-584-9919

INSPECTOR COMMENTS: Need Water & Heaters
Hooked up & valves installed

PASS FAIL

DATE: 5-12-21

TIME: 1:30

INSPECTOR: RBB 3330

☒ Re-Inspection Fee Required

Jimmy LaBrayer - 2-723 5254

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 5-11-21 TIME : AM / PM

PROPERTY ADDRESS: 531 Piney Point Road

PERMIT NUMBER: 16731

- | | | |
|---|-------------------------------|---|
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Street Clean In Front of Property- (Nothing in Gutter) |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Dirt, Mud, Construction Tracks in Front of Property |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Trash Anywhere on Property |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down! |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Dumpster full to the Lip & Needs to be Serviced |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Port-O-Can Door Facing Away From Street |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Port-O-Can Screened and/or Needs Maintenance |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Tree Protective Fencing Down |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Filter Fabric Fencing Down |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | High Grass and/or Tall Weeds |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Overall Condition of Construction Site <u> </u> Good <u> </u> Poor |
| <u> </u> Verbal Warning <u> </u> Site Cleaned at Insp. <u> </u> City Citation Issued <u> </u> City Notified | | |

DATE: TIME AM/PM

INSPECTOR : 1) Jason Bienek 2) Bob Baldwin

INSPECTION TYPE

- | | | | | |
|----------------------------|--------------------------|---|-------------------------------|--------------------------|
| 1. PRE CONSTRUCTION SITE | <input type="checkbox"/> | <div style="font-size: 2em; font-family: cursive;">GTO</div> <div style="font-size: 2em; font-family: cursive;">MAIN</div> <div style="font-size: 2em; font-family: cursive;">HOUSE</div> | 1. POOL STAKE OUT/POOL SET-UP | <input type="checkbox"/> |
| 2. PIERS | <input type="checkbox"/> | | 2. POOL STEEL | <input type="checkbox"/> |
| 3. FOUNDATION STEEL | <input type="checkbox"/> | | 3. POOL DECK/PATIO STEEL | <input type="checkbox"/> |
| 4. RIDGE HEIGHT | <input type="checkbox"/> | | 4. POOL BARRIER | <input type="checkbox"/> |
| 5. HURRICANE TIES | <input type="checkbox"/> | | 4. POOL FINAL | <input type="checkbox"/> |
| 6. STUCCO LATHE/BRICK TIES | <input type="checkbox"/> | | 1. FENCE POST HOLE | <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER | <input type="checkbox"/> | | 2. FENCE FINAL | <input type="checkbox"/> |
| 8. BUILDING FINAL | <input type="checkbox"/> | | 1. DRIVEWAY/FLATWORK FORMS | <input type="checkbox"/> |
| 9. TREE FINAL | <input type="checkbox"/> | | 2. DRIVEWAY FINAL | <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL | <input type="checkbox"/> | | 3. OTHER | <input type="checkbox"/> |
| 11. Generator Steel | <input type="checkbox"/> | | 4. TRENCH | <input type="checkbox"/> |
| 12. Generator Final | <input type="checkbox"/> | | 5. TEMP FENCING | <input type="checkbox"/> |

CONTRACTOR/CALLER NAME: Triple G Plumbing

CONTACT TEL/PGR/MOBILE: John 7-584-9919

INSPECTOR COMMENTS:

Plug down stairs
dryer line. Pressure too low. 17 lbs.
will work.

PASS	FAIL
DATE: <u>5-11-21</u>	
TIME: <u>10:15</u>	
INSPECTOR: <u>BBB 3330</u>	

☐ Reinspection fee required