

REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-10-21 TIME 10:30: AM / PM

JOB ADDRESS: 11120 Memorial

PERMIT NUMBER: 17195

INSPECTION DATE:

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection ☐
- 2. T-pole ☐
- 3. Ditch Cover ☐
- 4. Slab Cover ☐
- 5. Wall / Ceiling Cover ☐
- 6. TCI ☐
- 7. Meter Loop And Service ☐
- 8. Reconnect ☐
- 9. Electrical Final ☐
- 10. Landscape Lighting Cover ☐
- 11. Landscape Lighting Final ☐

- 1. Electrical Pool Cover ☐
- 2. Electrical Pool Final ☐
- 1. Generator Ditch Cover ☐
- 2. Generator Electrical Final ☐
- 1. Partial / See Comments ☐

PASS	FAIL
DATE:	<u>2-10-21</u>
TIME:	<u>10:30</u>
INSPECTOR:	<u>JB</u>

CONTRACTOR/CALLER NAME: North Electric

CONTACT TEL/PGR/MOBILE: Chris 281-879-6668

INSPECTOR COMMENTS:

Open wiring by filter
Open wiring @ Pool

☒ Reinspection fee required