

REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-25-21 TIME 12:00: AM / PM

JOB ADDRESS: 20 Fairham Park

PERMIT NUMBER: 16215

INSPECTION DATE:

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTOR: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection ☐
- 2. T-pole ☐
- 3. Ditch Cover ☐
- 4. Slab Cover ☐
- 5. Wall / Ceiling Cover ☐
- 6. TCI ☐
- 7. Meter Loop And Service ☐
- 8. ~~Reconnect~~ ☐
- 9. Electrical Final ☐
- 10. Landscape Lighting Cover ☐
- 11. Landscape Lighting Final ☐

- 1. Electrical Pool Cover ☐
- 2. Electrical Pool Final ☐
- 1. Generator Ditch Cover ☐
- 2. Generator Electrical Final ☐
- 1. Partial / See Comments ☐

PASS

FAIL

DATE: 2-25-21

TIME: 12:00

INSPECTOR: FB

CONTRACTOR/CALLER NAME: Amic Electric

CONTACT TEL/PGR/MOBILE: Amia 281-796-4085

INSPECTOR COMMENTS:

☐ Reinspection fee required

REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-10-21 TIME 11:30 AM / PM

JOB ADDRESS: 20 Fraenham Park

PERMIT NUMBER: 16215

INSPECTION DATE:

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection ☐
- 2. T-pole ☐
- 3. Ditch Cover ☐
- 4. Slab Cover ☐
- 5. Wall / Ceiling Cover ☐
- 6. TCI ☐
- 7. Meter Loop And Service ☐
- 8. Reconnect ☐
- 9. Electrical Final ☐
- 10. Landscape Lighting Cover ☐
- 11. Landscape Lighting Final ☐

- 1. Electrical Pool Cover ☐
- 2. Electrical Pool Final ☐
- 1. Generator Ditch Cover ☐
- 2. Generator Electrical Final ☐
- 1. Partial / See Comments ☐

PASS

FAIL

DATE: 2-10-21

TIME: 11:30

INSPECTOR: FB

CONTRACTOR/CALLER NAME: Amir Electric

CONTACT TEL/PGR/MOBILE: Amir 281-796-4085

INSPECTOR COMMENTS:

Kitchen outlets more than 20" above
Countertop

Wiring Panel lids loose need to be
secured

☒ Reinspection fee required