

REQUEST FOR ELECTRICAL INSPECTION

DATE: 7-3-21 TIME 9:20: AM / PM

JOB ADDRESS: 218 Millbrook

PERMIT NUMBER: 17621

INSPECTION DATE:

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection ☐
- 2. T-pole ☐
- 3. Ditch Cover ☐
- 4. Slab Cover ☐
- 5. Wall / Ceiling Cover ☐
- 6. TCI ☐
- 7. Meter Loop And Service ☐
- 8. Reconnect ☐
- 9. Electrical Final ☐
- 10. Landscape Lighting Cover ☐
- 11. Landscape Lighting Final ☐

- 1. Electrical Pool Cover ☐
- 2. Electrical Pool Final ☐
- 1. Generator Ditch Cover ☐
- 2. Generator Electrical Final ☐
- 1. Partial / See Comments ☐

PASS

FAIL

DATE: 7-3-21

TIME: 9:20

INSPECTOR: JB

CONTRACTOR/CALLER NAME: Highlander Electrical

CONTACT TEL/PGR/MOBILE: Juan 832-417-8709

INSPECTOR COMMENTS:

9-21 Released to Centepoint 23-21
William

☐ Reinspection fee required