

# REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-24-21 TIME 10:30 AM / PM

JOB ADDRESS: 5 hACEWOOD

PERMIT NUMBER: 17627

INSPECTION DATE:

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTOR: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection ☐
- 2. T-pole ☐
- 3. Ditch Cover ☐
- 4. Slab Cover ☐
- 5. Wall / Celing Cover ☐
- 6. TCI ☐
- 7. Meter Loop And Service ☐
- 8. Reconnect ☐
- 9. Electrical Final ☐
- 10. Landscape Lighting Cover ☐
- 11. Landscape Lighting Final ☐

- 1. Electrical Pool Cover ☐
- 2. Electrical Pool Final ☐
- 1. Generator Ditch Cover ☐
- 2. Generator Electrical Final ☐
- 1. Partial / See Comments ☐

|                                          |                               |
|------------------------------------------|-------------------------------|
| <input checked="" type="checkbox"/> PASS | <input type="checkbox"/> FAIL |
| DATE: <u>2-24-21</u>                     |                               |
| TIME: <u>10:30</u>                       |                               |
| INSPECTOR: <u>JB</u>                     |                               |

CONTRACTOR/CALLER NAME: Method Wiring

CONTACT TEL/PGR/MOBILE: Derek

INSPECTOR COMMENTS:

☐ Reinspection fee required



# REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-12-21 TIME 12:00 : AM / PM

JOB ADDRESS: 5 HACEWOOD

PERMIT NUMBER: 17627

INSPECTION DATE:

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection ☐
- 2. T-pole ☐
- 3. Ditch Cover ☐
- 4. Slab Cover ☐
- 5. Wall / Ceiling Cover ☐
- 6. TCI ☐
- 7. Meter Loop And Service ☐
- 8. Reconnect ☐
- 9. Electrical Final ☐
- 10. Landscape Lighting Cover ☐
- 11. Landscape Lighting Final ☐

- 1. Electrical Pool Cover ☐
- 2. Electrical Pool Final ☐
- 1. Generator Ditch Cover ☐
- 2. Generator Electrical Final ☐
- 1. Partial / See Comments ☐

PASS

**FAIL**

DATE: 2-12-21

TIME: 12:00

INSPECTOR: FB

CONTRACTOR/CALLER NAME: Method Wiring

CONTACT TEL/PGR/MOBILE: Derek 713-885-5580

INSPECTOR COMMENTS:

Need to Add plugs @ Entry (3)  
Need to Band Metal Boxes  
Need UF or THHN wiring to island  
Need to insulate wiring from metal piping  
Need to Add plugs @ 2nd Floor Dormers  
Need to Add plugs @ 2nd Floor Landing Room  
Need to Clean up wires in attic where  
more than 3' of overhead clearance

☒ Reinspection fee required