

Medh

2-25-21

5 Lacewood Lono

17648

2-25-21

NFPA 70 - NEC 2017

2) Bob Baldwin

1. Temp Sump Pump Connection ☐
2. T-pole ☐
3. Ditch Cover ☐
4. Slab Cover ☐
5. Wall / Celing Cover ☐
6. TCI ☐
7. Meter Loop And Service ☐
8. Reconnect ☐
9. Electrical Final ☐
10. Landscape Lighting Cover ☐
11. Landscape Lighting Final ☐

Mechanical Rough in

- | | |
|-------------------------------|--------------------------|
| 1. Electrical Pool Cover | ☐ |
| 2. Electrical Pool Final | ☐ |
| 1. Generator Ditch Cover | ☐ |
| 2. Generator Electrical Final | ☐ |
| 1. Partial / See Comments | ☐ |

FAIL

2-25-21

2:05

Bob R

INSPECTOR: Bob B

Turbo Air Conditioning & Heating

732 455 1804

832 455 1804

INSPECTOR COMMENTS:

☐ Reinspection fee required

Mech
REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-23-21 TIME: _____ : AM / PM

JOB ADDRESS: 5 Laceywood Lane

PERMIT NUMBER: 17648

INSPECTION DATE: 2-23-21

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection ☐
- 2. T-pole ☐
- 3. Ditch Cover ☐
- 4. Slab Cover ☐
- 5. Wall / Ceiling Cover ☐
- 6. TCI ☐
- 7. Meter Loop And Service ☐
- 8. Reconnect ☐
- 9. Electrical Final ☐
- 10. Landscape Lighting Cover ☐
- 11. Landscape Lighting Final ☐

*Mechanical
Rough in*

- 1. Electrical Pool Cover ☐
- 2. Electrical Pool Final ☐
- 1. Generator Ditch Cover ☐
- 2. Generator Electrical Final ☐
- 1. Partial / See Comments ☐

PASS

FAIL

DATE: 2-23-21

TIME: 9:15

INSPECTOR: B.B.B.

CONTRACTOR/CALLER NAME: Turbo AC & Heating

CONTACT TEL/PGR/MOBILE: 832-455-1804

INSPECTOR COMMENTS:

*Need Kitchen Make up Air
Vent exhaust fans out of structure.*

*Kyle Hobbs
713-249-0963*

☐ Reinspection fee required