

REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 2-21-10-21 TIME: 2 : 00 AM / PM

JOB ADDRESS: 11306 Claymore Rd

PERMIT NUMBER: 17328

- ☐ Pass ☐ Fail Street Clean In Front of Property- (Nothing in Gutter)
☐ Pass ☐ Fail Dirt, Mud, Construction Tracks in Front of Property
☐ Pass ☐ Fail Trash Anywhere on Property
☐ Pass ☐ Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
☐ Pass ☐ Fail Dumpster full to the Lip & Needs to be Serviced
☐ Pass ☐ Fail Port-O-Can Door Facing Away From Street
☐ Pass ☐ Fail Port-O-Can Screened and/or Needs Maintenance
☐ Pass ☐ Fail Tree Protective Fencing Down
☐ Pass ☐ Fail Filter Fabric Fencing Down
☐ Pass ☐ Fail High Grass and/or Tall Weeds
☐ Pass ☐ Fail Overall Condition of Construction Site Good Poor
Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

INSPECTOR : Bob Baldwin

INSPECTION DATE: 2-10-21

PLUMBING

1. Water line ☐
2. Rough In ☐
3. Top Out ☐
4. Shower Pan ☐
5. Sewer Line ☐
6. WC Flange ☐
7. GTO ☐
8. Plumbing Final ☐
9. Pool Drainage ☐
- 10 Site Drainage ☐
11. Irrigation Final ☒
12. Other ☐

MECHANICAL

1. Vent Hood ☐
2. Rough/cover ☐
3. Mech Final ☐
4. Water Heater Final ☐
5. Fire Sprinkler cover ☐
(need MVFD approval)
6. Fire Sprinkler Final ☐

PASS

FAIL

DATE: 2-10-21

TIME: 10:30

INSPECTOR: Bb B 3330

CONTRACTOR/CALLER NAME: Smart Water Works

CONTACT TEL/PGR/MOBILE: 832 397 7360

INSPECTOR COMMENTS: Missing hose bib vacuum breaker
in back yard. Water heater T & A
drain pipes must terminate no more
than 6 inches above ground.

☒ Reinspection fee required

Plumbing

DATE: 2-10-21

JOB ADDRESS: 11306 Claymore Road

PERMIT NUMBER: 17113

INSPECTION DATE: _____

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- # Plumbing
- ## Final

- | | |
|-------------------------------|--------------------------|
| 1. Electrical Pool Cover | <input type="checkbox"/> |
| 2. Electrical Pool Final | <input type="checkbox"/> |
| 1. Generator Ditch Cover | <input type="checkbox"/> |
| 2. Generator Electrical Final | <input type="checkbox"/> |
| 1. Partial / See Comments | <input type="checkbox"/> |

PASS	FAIL
DATE:	2-10-25
TIME:	10:40
INSPECTOR:	K-B 3330

CONTRACTOR/CALLER NAME: Big Johns Plumbing

CONTACT TEL/PGR/MOBILE: 281 984 8227

INSPECTOR COMMENTS: _____

☐ Reinspection fee required