

Plumbing

REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-22-21 TIME: 10:15 : AM / PM

JOB ADDRESS: 11537 Raintree Circle

PERMIT NUMBER: 17117

INSPECTION DATE: 2-22-21

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection ☐
- 2. T-pole ☐
- 3. Ditch Cover ☐
- 4. Slab Cover ☐
- 5. Wall / Ceiling Cover ☐
- 6. TCI ☐
- 7. Meter Loop And Service ☐
- 8. Reconnect ☐
- 9. Electrical Final ☐
- 10. Landscape Lighting Cover ☐
- 11. Landscape Lighting Final ☐

Plumbing
Generator
Gas

- 1. Electrical Pool Cover ☐
- 2. Electrical Pool Final ☐
- 1. Generator Ditch Cover ☐
- 2. Generator Electrical Final ☐
- 1. Partial / See Comments ☐

PASS	FAIL
DATE: <u>2-22-21</u>	
TIME: <u>10:15</u>	
INSPECTOR: <u>BBB 3334</u>	

CONTRACTOR/CALLER NAME: iPlumb

CONTACT TEL/PGR/MOBILE: 713 473 1300

INSPECTOR COMMENTS:

☐ Reinspection fee required

Plumbing

REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-10-21 TIME 10:05 : AM / PM
JOB ADDRESS: 11537 Paintree Circle
PERMIT NUMBER: 17117

INSPECTION DATE: 2-10-21 Codes Used: NFPA 70 - NEC 2017

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

1. Temp Sump Pump Connection ☐

2. T-pole ☐

3. Ditch Cover ☐

4. Slab Cover ☐

5. Wall / Celing Cover ☐

6. TCI ☐

7. Meter Loop And Service ☐

8. Reconnect ☐

9. Electrical Final ☐

10. Landscape Lighting Cover ☐

11. Landscape Lighting Final ☐

Plumbing
GTO
1. Electrical Pool Cover ☐

2. Electrical Pool Final ☐

1. Generator Ditch Cover ☐

2. Generator Electrical Final ☐

1. Partial / See Comments ☐

PASS	FAIL
DATE: 2-10-21	
TIME: 10:05	
INSPECTOR: BHB 3330	

CONTRACTOR/CALLER NAME: i Plumb
CONTACT TEL/PGR/MOBILE: 713 473 1300 Isaac
INSPECTOR COMMENTS:

Only has 3.5 lbs
of pressure.
Need at least 12 lbs.

☒ Reinspection fee required