

Drainage

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 02.3.2021 TIME : AM / PM

PROPERTY ADDRESS: 213 Millbrook Street

PERMIT NUMBER: Presley - P#17589/ temp drainage

- | | | |
|---|-------------------------------|---|
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Street Clean In Front of Property- (Nothing in Gutter) |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Dirt, Mud, Construction Tracks in Front of Property |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Trash Anywhere on Property |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down! |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Dumpster full to the Lip & Needs to be Serviced |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Port-O-Can Door Facing Away From Street |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Port-O-Can Screened and/or Needs Maintenance |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Tree Protective Fencing Down |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Filter Fabric Fencing Down |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | High Grass and/or Tall Weeds |
| <input type="checkbox"/> Pass | <input type="checkbox"/> Fail | Overall Condition of Construction Site <u> </u> Good <u> </u> Poor |
| <u> </u> Verbal Warning <u> </u> Site Cleaned at Insp. <u> </u> City Citation Issued <u> </u> City Notified | | |

Thursday

DATE: 02.4.2021 TIME AM/PM

INSPECTOR : 1) Jason Bienek Presley w/ HDE engin 2) Bob Baldwin

INSPECTION TYPE

- | | |
|---|--|
| 1. PRE CONSTRUCTION SITE <input type="checkbox"/> | 1. POOL STAKE OUT/POOL SET-UP <input type="checkbox"/> |
| 2. PIERS <input type="checkbox"/> | 2. POOL STEEL <input type="checkbox"/> |
| 3. FOUNDATION STEEL <input type="checkbox"/> | 3. POOL DECK/PATIO STEEL <input type="checkbox"/> |
| 4. RIDGE HEIGHT <input type="checkbox"/> | 4. POOL BARRIER <input type="checkbox"/> |
| 5. HURRICANE TIES <input type="checkbox"/> | 4. POOL FINAL <input type="checkbox"/> |
| 6. STUCCO LATHE/BRICK TIES <input type="checkbox"/> | 1. FENCE POST HOLE <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER <input type="checkbox"/> | 2. FENCE FINAL <input type="checkbox"/> |
| 8. BUILDING FINAL <input type="checkbox"/> | 1. DRIVEWAY/FLATWORK FORMS <input type="checkbox"/> |
| 9. TREE FINAL <input type="checkbox"/> | 2. DRIVEWAY FINAL <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL <input type="checkbox"/> | 3. OTHER <input type="checkbox"/> |
| 11. Generator Steel <input type="checkbox"/> | 4. TRENCH <input checked="" type="checkbox"/> |
| 12. Generator Final <input type="checkbox"/> | 5. TEMP FENCING <input type="checkbox"/> |

CONTRACTOR/CALLER NAME: Fraser Homes

CONTACT TEL/PGR/MOBILE: Scott Fraser (7) 8167714

INSPECTOR COMMENTS: Site drainage
temp.

PASS

FAIL

DATE: 2/4/2021

TIME: 11:35

INSPECTOR: Presley L.

- Alot of undersized pipes, contractor has old plans
can cover pipes that are sized OK, walked
with Greg
sump pump not in & installed & working
no drainage outfall

☐ Reinspection fee required