

Plumbing

REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-12-21 TIME: 10:40 AM / PM

JOB ADDRESS: 327 Tynebridge

PERMIT NUMBER: 16867

INSPECTION DATE: 2-12-21

Codes Used: NFPA 70 - NEC 2017

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection ☐
- 2. T-pole ☐
- 3. Ditch Cover ☐
- 4. Slab Cover ☐
- 5. Wall / Ceiling Cover ☐
- 6. TCI ☐
- 7. Meter Loop And Service ☐
- 8. Reconnect ☐
- 9. Electrical Final ☐
- 10. Landscape Lighting Cover ☐
- 11. Landscape Lighting Final ☐

Final Plumbing

- 1. Electrical Pool Cover ☐
- 2. Electrical Pool Final ☐
- 1. Generator Ditch Cover ☐
- 2. Generator Electrical Final ☐
- 1. Partial / See Comments ☐

|                     |      |
|---------------------|------|
| PASS                | FAIL |
| DATE: 2-12-21       |      |
| TIME: 10:40         |      |
| INSPECTOR: BJB 3330 |      |

CONTRACTOR/CALLER NAME: Advanced Creations

CONTACT TEL/PGR/MOBILE: 713 882 1010

INSPECTOR COMMENTS: Need hot water heater working & Install vacuum breakers on all hose bibs.

☒ Reinspection fee required