

Plumbing

REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-24-21 TIME: : AM / PM

JOB ADDRESS: 5 Lacewood

PERMIT NUMBER: 17598

INSPECTION DATE: 2-24-21

Codes Used: NFPA 70 - NEC 2017

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection ☐
- 2. T-pole ☐
- 3. Ditch Cover ☐
- 4. Slab Cover ☐
- 5. Wall / Ceiling Cover ☐
- 6. TCI ☐
- 7. Meter Loop And Service ☐
- 8. Reconnect ☐
- 9. Electrical Final ☐
- 10. Landscape Lighting Cover ☐
- 11. Landscape Lighting Final ☐

Plumbing
Rough in

- 1. Electrical Pool Cover ☐
- 2. Electrical Pool Final ☐
- 1. Generator Ditch Cover ☐
- 2. Generator Electrical Final ☐
- 1. Partial / See Comments ☐

PASS	FAIL
DATE: 2-24-21	
TIME: 3:00	
INSPECTOR: Bob 3330	

CONTRACTOR/CALLER NAME: Southern Plumbing

CONTACT TEL/PGR/MOBILE: 832 231 7521

INSPECTOR COMMENTS:

Need to install vacuum
breakers on all hose bibs.

☐ Reinspection fee required