

REQUEST FOR ELECTRICAL INSPECTION

DATE: 2-24-21 TIME 10:50 : AM / PM

JOB ADDRESS: 8502 San Felipe

PERMIT NUMBER: 17567

INSPECTION DATE: 2-24-21

Codes Used: NFPA 70 - NEC 2017

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- 1. Temp Sump Pump Connection ☐
- 2. T-pole ☐
- 3. Ditch Cover ☐
- 4. Slab Cover ☐
- 5. Wall / Ceiling Cover ☐
- 6. TCI ☐
- 7. Meter Loop And Service ☐
- 8. Reconnect ☐
- 9. Electrical Final ☐
- 10. Landscape Lighting Cover ☐
- 11. Landscape Lighting Final ☐

- 1. Electrical Pool Cover ☐
- 2. Electrical Pool Final ☐
- 1. Generator Ditch Cover ☐
- 2. Generator Electrical Final ☐
- 1. Partial / See Comments ☐

PASS	FAIL
DATE: 2-24-21	
TIME: 10:50	
INSPECTOR: RJTB 3330	

CONTRACTOR/CALLER NAME: RJTB Plumbing

CONTACT TEL/PGR/MOBILE: 346 333 8836

TL Gray

INSPECTOR COMMENTS:

Cover pipes in upstairs bath. Install vacuum breakers on all hose bibs on property. Uncover valve for fireplace.

☒ Reinspection fee required