

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 2-23-21 TIME 12:09 AM / PM

PROPERTY ADDRESS: 242 Black

PERMIT NUMBER: 17634

- ☐ Pass ☐ Fail Street Clean In Front of Property- (Nothing in Gutter)
☐ Pass ☐ Fail Dirt, Mud, Construction Tracks in Front of Property
☐ Pass ☐ Fail Trash Anywhere on Property
☐ Pass ☐ Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
☐ Pass ☐ Fail Dumpster full to the Lip & Needs to be Serviced
☐ Pass ☐ Fail Port-O-Can Door Facing Away From Street
☐ Pass ☐ Fail Port-O-Can Screened and/or Needs Maintenance
☐ Pass ☐ Fail Tree Protective Fencing Down
☐ Pass ☐ Fail Filter Fabric Fencing Down
☐ Pass ☐ Fail High Grass and/or Tall Weeds
☐ Pass ☐ Fail Overall Condition of Construction Site Good Poor
Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 2-23-21 TIME 12:09 AM/PM

INSPECTOR : 1) Jason Bienek 2) Bob Baldwin

INSPECTION TYPE

- | | | | |
|----------------------------|--------------------------|-------------------------------|--------------------------|
| 1. PRE CONSTRUCTION SITE | <input type="checkbox"/> | 1. POOL STAKE OUT/POOL SET-UP | <input type="checkbox"/> |
| 2. PIERS | <input type="checkbox"/> | 2. POOL STEEL | <input type="checkbox"/> |
| 3. FOUNDATION STEEL | <input type="checkbox"/> | 3. POOL DECK/PATIO STEEL | <input type="checkbox"/> |
| 4. RIDGE HEIGHT | <input type="checkbox"/> | 4. POOL BARRIER | <input type="checkbox"/> |
| 5. HURRICANE TIES | <input type="checkbox"/> | 4. POOL FINAL | <input type="checkbox"/> |
| 6. STUCCO LATHE/BRICK TIES | <input type="checkbox"/> | 1. FENCE POST HOLE | <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER | <input type="checkbox"/> | 2. FENCE FINAL | <input type="checkbox"/> |
| 8. BUILDING FINAL | <input type="checkbox"/> | 1. DRIVEWAY/SLABWORK FORMS | <input type="checkbox"/> |
| 9. TREE FINAL | <input type="checkbox"/> | 2. DRIVEWAY FINAL | <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL | <input type="checkbox"/> | 3. OTHER | <input type="checkbox"/> |
| 11. Generator Steel | <input type="checkbox"/> | 4. TRENCH | <input type="checkbox"/> |
| 12. Generator Final | <input type="checkbox"/> | 5. TEMP FENCING | <input type="checkbox"/> |

CONTRACTOR/CALLER NAME: Eduardo

CONTACT TEL/PGR/MOBILE: None

INSPECTOR COMMENTS: 832-276-6088

PASS

FAIL

DATE

TIME:

INSPECTOR:

☐ Reinspection fee required

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 2-22-21 TIME 10:30 AM / PM

PROPERTY ADDRESS: 242 B block

PERMIT NUMBER: 17634

- ☐ Pass ☐ Fail Street Clean In Front of Property- (Nothing in Gutter)
☐ Pass ☐ Fail Dirt, Mud, Construction Tracks in Front of Property
☐ Pass ☐ Fail Trash Anywhere on Property
☐ Pass ☐ Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
☐ Pass ☐ Fail Dumpster full to the Lip & Needs to be Serviced
☐ Pass ☐ Fail Port-O-Can Door Facing Away From Street
☐ Pass ☐ Fail Port-O-Can Screened and/or Needs Maintenance
☐ Pass ☐ Fail Tree Protective Fencing Down
☐ Pass ☐ Fail Filter Fabric Fencing Down
☐ Pass ☐ Fail High Grass and/or Tall Weeds
☐ Pass ☐ Fail Overall Condition of Construction Site Good Poor
Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: 2-22-21 TIME 10:30 AM/PM

INSPECTOR: Jason Bienek 2) Bob Baldwin

INSPECTION TYPE

- | | | | |
|----------------------------|--------------------------|-------------------------------|--------------------------|
| 1. PRE CONSTRUCTION SITE | <input type="checkbox"/> | 1. POOL STAKE OUT/POOL SET-UP | <input type="checkbox"/> |
| 2. PIERS | <input type="checkbox"/> | 2. POOL STEEL | <input type="checkbox"/> |
| 3. FOUNDATION STEEL | <input type="checkbox"/> | 3. POOL DECK/PATIO STEEL | <input type="checkbox"/> |
| 4. RIDGE HEIGHT | <input type="checkbox"/> | 4. POOL BARRIER | <input type="checkbox"/> |
| 5. HURRICANE TIES | <input type="checkbox"/> | 4. POOL FINAL | <input type="checkbox"/> |
| 6. STUCCO LATHE/BRICK TIES | <input type="checkbox"/> | 1. FENCE POST HOLE | <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER | <input type="checkbox"/> | 2. FENCE FINAL | <input type="checkbox"/> |
| 8. BUILDING FINAL | <input type="checkbox"/> | 1. DRIVEWAY/FLATWORK FORMS | <input type="checkbox"/> |
| 9. TREE FINAL | <input type="checkbox"/> | 2. DRIVEWAY FINAL | <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL | <input type="checkbox"/> | 3. OTHER | <input type="checkbox"/> |
| 11. Generator Steel | <input type="checkbox"/> | 4. TRENCH | <input type="checkbox"/> |
| 12. Generator Final | <input type="checkbox"/> | 5. TEMP FENCING | <input type="checkbox"/> |

CONTRACTOR/CALLER NAME: Eduardo

CONTACT TEL/PGR/MOBILE: 832-794-1515

INSPECTOR COMMENTS:

Expansion joints must go all the way down to dirt

PASS	<input checked="" type="radio"/> FAIL
DATE:	<u>2-22-21</u>
TIME:	<u>10:30</u>
INSPECTOR:	<u>JB</u>

☒ Reinspection fee required

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 2-11-21 TIME 10:25 AM / PM

PROPERTY ADDRESS: 242 Blalock

PERMIT NUMBER: 17634

- ☐ Pass ☐ Fail Street Clean In Front of Property- (Nothing in Gutter)
☐ Pass ☐ Fail Dirt, Mud, Construction Tracks in Front of Property
☐ Pass ☐ Fail Trash Anywhere on Property
☐ Pass ☐ Fail O-Tolerance for Lunch Trash This May Result in
Project to be Temporarily Shut Down!
☐ Pass ☐ Fail Dumpster full to the Lip & Needs to be Serviced
☐ Pass ☐ Fail Port-O-Can Door Facing Away From Street
☐ Pass ☐ Fail Port-O-Can Screened and/or Needs Maintenance
☐ Pass ☐ Fail Tree Protective Fencing Down
☐ Pass ☐ Fail Filter Fabric Fencing Down
☐ Pass ☐ Fail High Grass and/or Tall Weeds
☐ Pass ☐ Fail Overall Condition of Construction Site Good Poor
Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: _____ TIME _____ AM/PM

INSPECTOR (1) Jason Bienek 2) Bob Baldwin

INSPECTION TYPE

- | | | | |
|----------------------------|--------------------------|-------------------------------|--------------------------|
| 1. PRE CONSTRUCTION SITE | <input type="checkbox"/> | 1. POOL STAKE OUT/POOL SET-UP | <input type="checkbox"/> |
| 2. PIERS | <input type="checkbox"/> | 2. POOL STEEL | <input type="checkbox"/> |
| 3. FOUNDATION STEEL | <input type="checkbox"/> | 3. POOL DECK/PATIO STEEL | <input type="checkbox"/> |
| 4. RIDGE HEIGHT | <input type="checkbox"/> | 4. POOL BARRIER | <input type="checkbox"/> |
| 5. HURRICANE TIES | <input type="checkbox"/> | 4. POOL FINAL | <input type="checkbox"/> |
| 6. STUCCO LATHE/BRICK TIES | <input type="checkbox"/> | 1. FENCE POST HOLE | <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER | <input type="checkbox"/> | 2. FENCE FINAL | <input type="checkbox"/> |
| 8. BUILDING FINAL | <input type="checkbox"/> | 1. DRIVEWAY / PLATWORK FORMS | <input type="checkbox"/> |
| 9. TREE FINAL | <input type="checkbox"/> | 2. DRIVEWAY FINAL | <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL | <input type="checkbox"/> | 3. OTHER | <input type="checkbox"/> |
| 11. Generator Steel | <input type="checkbox"/> | 4. TRENCH | <input type="checkbox"/> |
| 12. Generator Final | <input type="checkbox"/> | 5. TEMP FENCING | <input type="checkbox"/> |

CONTRACTOR/CALLER NAME: Eduardos Concrete

CONTACT TEL/PGR/MOBILE: Eduardo

INSPECTOR COMMENTS: 832-276-6088

Neil- 832-276-6088

PASS	<u>FAIL</u>
DATE:	<u>2-11-21</u>
TIME:	<u>10:25</u>
INSPECTOR:	<u>JB</u>

Concrete must be 5" thick
Expansion joints must go all the way to dirt
Need pin (sleeve @ expansion joint)

☒ Reinspection fee required