

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 2-23-21 TIME 9:00 AM / PM

PROPERTY ADDRESS: 367 Robbins

PERMIT NUMBER: 17625

- ☐ Pass ☐ Fail Street Clean In Front of Property- (Nothing in Gutter)
☐ Pass ☐ Fail Dirt, Mud, Construction Tracks in Front of Property
☐ Pass ☐ Fail Trash Anywhere on Property
☐ Pass ☐ Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
☐ Pass ☐ Fail Dumpster full to the Lip & Needs to be Serviced
☐ Pass ☐ Fail Port-O-Can Door Facing Away From Street
☐ Pass ☐ Fail Port-O-Can Screened and/or Needs Maintenance
☐ Pass ☐ Fail Tree Protective Fencing Down
☐ Pass ☐ Fail Filter Fabric Fencing Down
☐ Pass ☐ Fail High Grass and/or Tall Weeds
☐ Pass ☐ Fail Overall Condition of Construction Site Good Poor
Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: _____ TIME _____ AM/PM

INSPECTOR 1) Jason Bienek 2) Bob Baldwin

INSPECTION TYPE

- | | | | |
|----------------------------|--------------------------|-----------------------------------|--------------------------|
| 1. PRE CONSTRUCTION SITE | <input type="checkbox"/> | 1. POOL STAKE OUT/POOL SET-UP | <input type="checkbox"/> |
| 2. PIERS | <input type="checkbox"/> | 2. POOL STEEL | <input type="checkbox"/> |
| 3. FOUNDATION STEEL | <input type="checkbox"/> | 3. POOL DECK/PATIO STEEL | <input type="checkbox"/> |
| 4. RIDGE HEIGHT | <input type="checkbox"/> | 4. POOL BARRIER | <input type="checkbox"/> |
| 5. HURRICANE TIES | <input type="checkbox"/> | 4. POOL FINAL | <input type="checkbox"/> |
| 6. STUCCO LATHE/BRICK TIES | <input type="checkbox"/> | 1. FENCE POST HOLE | <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER | <input type="checkbox"/> | 2. FENCE FINAL | <input type="checkbox"/> |
| 8. BUILDING FINAL | <input type="checkbox"/> | <u>1. DRIVEWAY/FLATWORK FORMS</u> | <input type="checkbox"/> |
| 9. TREE FINAL | <input type="checkbox"/> | 2. DRIVEWAY FINAL | <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL | <input type="checkbox"/> | 3. OTHER | <input type="checkbox"/> |
| 11. Generator Steel | <input type="checkbox"/> | 4. TRENCH | <input type="checkbox"/> |
| 12. Generator Final | <input type="checkbox"/> | 5. TEMP FENCING | <input type="checkbox"/> |

CONTRACTOR/CALLER NAME: Paverife Pavers

CONTACT TEL/PGR/MOBILE: Nester

INSPECTOR COMMENTS: 713-873-1525

PASS **FAIL**

DATE: 2-23-21

TIME: 9:00

INSPECTOR: TB

☐ Reinspection fee required

REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 2-22-21 TIME 11:30 AM / PM

PROPERTY ADDRESS: 367 Robbins

PERMIT NUMBER: 17625

- ☐ Pass ☐ Fail Street Clean In Front of Property- (Nothing in Gutter)
☐ Pass ☐ Fail Dirt, Mud, Construction Tracks in Front of Property
☐ Pass ☐ Fail Trash Anywhere on Property
☐ Pass ☐ Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
☐ Pass ☐ Fail Dumpster full to the Lip & Needs to be Serviced
☐ Pass ☐ Fail Port-O-Can Door Facing Away From Street
☐ Pass ☐ Fail Port-O-Can Screened and/or Needs Maintenance
☐ Pass ☐ Fail Tree Protective Fencing Down
☐ Pass ☐ Fail Filter Fabric Fencing Down
☐ Pass ☐ Fail High Grass and/or Tall Weeds
☐ Pass ☐ Fail Overall Condition of Construction Site Good Poor
Verbal Warning Site Cleaned at Insp. City Citation Issued City Notified

DATE: _____ TIME _____ AM/PM

INSPECTOR 1) Jason Bienek 2) Bob Baldwin

INSPECTION TYPE

- | | | | |
|----------------------------|--------------------------|-------------------------------|--------------------------|
| 1. PRE CONSTRUCTION SITE | <input type="checkbox"/> | 1. POOL STAKE OUT/POOL SET-UP | <input type="checkbox"/> |
| 2. PIERS | <input type="checkbox"/> | 2. POOL STEEL | <input type="checkbox"/> |
| 3. FOUNDATION STEEL | <input type="checkbox"/> | 3. POOL DECK/PATIO STEEL | <input type="checkbox"/> |
| 4. RIDGE HEIGHT | <input type="checkbox"/> | 4. POOL BARRIER | <input type="checkbox"/> |
| 5. HURRICANE TIES | <input type="checkbox"/> | 4. POOL FINAL | <input type="checkbox"/> |
| 6. STUCCO LATHE/BRICK TIES | <input type="checkbox"/> | 1. FENCE POST HOLE | <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER | <input type="checkbox"/> | 2. FENCE FINAL | <input type="checkbox"/> |
| 8. BUILDING FINAL | <input type="checkbox"/> | 1. DRIVEWAY/FLATWORK FORMS | <input type="checkbox"/> |
| 9. TREE FINAL | <input type="checkbox"/> | 2. DRIVEWAY FINAL | <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL | <input type="checkbox"/> | 3. OTHER | <input type="checkbox"/> |
| 11. Generator Steel | <input type="checkbox"/> | 4. TRENCH | <input type="checkbox"/> |
| 12. Generator Final | <input type="checkbox"/> | 5. TEMP FENCING | <input type="checkbox"/> |

CONTRACTOR/CALLER NAME: Daveite Dances

CONTACT TEL/PGR/MOBILE: Dexter

INSPECTOR COMMENTS: 713-873-1525

PASS	<u>FAIL</u>
DATE:	<u>2-22-21</u>
TIME:	<u>11:30</u>
INSPECTOR:	<u>JB</u>

Need Sand between Sections
Need to Cut Down Drive to 5" thick

☒ Reinspection fee required