

REQUEST FOR INSPECTION

CALL DATE: 4-13-21 TIME: 10:30 AM / PM

PROPERTY ADDRESS: 230 Black

PERMIT NUMBER: 17005

INSPECTION INFORMATION

DATE PERFORMED: 4-13-21 TIME: 10:30 AM / PM

INSPECTOR: 1) Bob Baldwin _____
 2) Cary Moran _____
 3) City Engineer _____
 4) Jason Bienek _____
 5) Other _____

Demolition (Main House)	Sidewalk/Flatwork/Pavers Steel	Electrical Ditch Cover
Demolition (Pool Only)	Sidewalk/Flatwork/Paver Final	Electrical TCI
Temporary Tree Protection Fencing	Generator Concrete Steel Pad	Electrical Final
Pre-Construction Site	Generator Final - Operative	Mechanical Vent Hood
Piers	Partial Trench Inspection	Mechanical Grill Seal
Foundation Repair	Trench Inspection	Mechanical Box Seal
Foundation Steel – Survey Verified	Irrigation Final	Mechanical Air Make Up
Hurricane Strapping – Exterior Wall	Fence Partial Post Hole	Mechanical Final
Wall Board Exterior	Fence Post Hole	Mechanical Cover (Wine Room)
Ridge Height	Fence Final	Mechanical Final (Wine Room)
Stair Compliance	Temporary Drainage	Fire Sprinkler Cover
Framing Only	Drainage Partial	Fire Sprinkler Final
Frame Cover	Drainage Cover	Pool Stake Out & Pool Doc Box Set Up
Poly Seal	Drainage Culvert	Deck Steel
Insulation	Drainage Final	Deck Final
Wall Board Interior	Plumbing Water Line	Pool Final
Brick Tie	Plumbing Sewer Line	Pool Electrical Underground
Stucco Lathe	Plumbing Ground	Pool Electrical Cover
Building Final	Plumbing Shower Pan/Wall Board	Pool Electrical Final
Tree Final	Plumbing Gas (GTO- House)	Pool Plumbing Cover
Driveway / Partial	Plumbing Cover	Pool Plumbing Vacuum Breaker, P-Trap, Gas Final
Driveway / Steel	Plumbing Final	Plumbing Pool Final
Driveway Final	Electrical T-Pole	Water Heater Final

CONTRACTOR NAME: E Diamond Electric

CONTACT PHONE/EMAIL: Jose 713-319-7803

INSPECTOR COMMENTS: Ginger

RELEASED to THEIA
@ Center point @ 10:30 on
4-13-21

PASS FAIL

DATE: 4-13-21

TIME: 10:30

INSPECTOR: Jason

☐ Re-Inspection Fee Required

REQUEST FOR ELECTRICAL INSPECTION

DATE: 4-9-21 TIME 8:00: AM / PM

JOB ADDRESS: 230 Blalock

PERMIT NUMBER: 17005

INSPECTION DATE:

Codes Used: **NFPA 70 - NEC 2017**

ELECTRICAL INSPECTORS: (1) Jason Bienek (2) Bob Baldwin

- 1. Temp Sump Pump Connection ☐
- 2. T-pole ☐
- 3. Ditch Cover ☐
- 4. Slab Cover ☐
- 5. Wall / Ceiling Cover ☐
- 6. TCI ☐
- 7. Meter Loop And Service ☐
- 8. Reconnect ☐
- 9. Electrical Final ☐
- 10. Landscape Lighting Cover ☐
- 11. Landscape Lighting Final ☐

- 1. Electrical Pool Cover ☐
- 2. Electrical Pool Final ☐
- 1. Generator Ditch Cover ☐
- 2. Generator Electrical Final ☐
- 1. Partial / See Comments ☐

PASS

FAIL

DATE: 4-9-21

TIME: 8:00

INSPECTOR: Jason

CONTRACTOR/CALLER NAME: Diamond Electrical

CONTACT TEL/PGR/MOBILE: Jose 713-319-7803

INSPECTOR COMMENTS:

1/0 wire not large enough for 200amps
Ground wire- need to be run into panel (DISC)
Neutral need to go on Neutral Bar in gutter
Wires Need to be tied together in gutter
for parallel service

☒ Reinspection fee required